

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED

OCT 2 2 1963 WATER WELL REPORT

STATE OF OREGON (Please type or print)

MULT 001369

11/3-28

State Well No.

State Permit No. G2460

(1) OWNER:

Name CITY OF FAIRVIEW
Address FAIRVIEW, OREGON

(2) LOCATION OF WELL:

County MULT Driller's well number 4157
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:

Threaded Welded
16" Diam. from 0 ft. to 298 ft. Gage .312
17" Diam. from 295 ft. to 355 ft. Gage .330

(7) PERFORATIONS:

Type of perforator used STAR IN 16 INCH
Size of perforations 3/8 in. by TORCH IN 16 INCH
400 perforations from 105 ft. to 115 ft.
780 perforations from 135 ft. to 152 ft.
770 perforations from 194 ft. to 205 ft.
40 perforations from 284 ft. to 295 ft.
360 perforations from 335 ft. to 350 ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT GROUT
Depth of seal 60 ft. Was a packer used? YES
Diameter of well bore to bottom of seal 20 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: 3/4 MINUS
Gravel placed from 298 ft. to 355 ft.
Did any strata contain unusable water? Yes No
Type of water? SURFACE Depth of strata 78 FT.
Method of sealing strata off CASING AND CEMENT

(10) WATER LEVELS:

Static level 68 ft. below land surface Date 10/4/63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? R.J.S.D. Co.
Yield: 325 gal./min. with 124 ft. drawdown after 8 hrs.
" 300 " 114 " 1/2 "
" 250 " 106 " 1/2 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 53° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing
Depth drilled 402 ft. Depth of completed well 355 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	2
ROCK OUT CRAPPING	2	8
COARSE GRAVEL	8	12
SAND, GRAVEL AND CLAY	12	40
BOULDERS AND CLAY	40	51
COARSE GRAVEL	51	63
SAND GRAVEL AND CLAY	63	89
CEMENTED GRAVEL	89	104
WATER BEARING GRAVEL	104	112
SLIGHTLY CEMENTED GRAVEL	112	135
WATER BEARING GRAVEL	135	152
CEMENTED GRAVEL	152	170
LARGE GRAVEL SOME BOULDERS	170	217
GREEN SHALE	217	277
BROWN CLAY STONE	277	289
SLIGHTLY CEMENTED GRAVEL	289	295
CEMENTED GRAVEL	295	316
SAND GRAVEL AND CLAY	316	364
CLAY AND GRAVEL	364	420

Work started JUNE 27 1963 Completed OCT 9 1963
Date well drilling machine moved off of well OCT 10 1963

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R.J. STRASSER DRILLING CO
(Person, firm or corporation) (Type or print)
Address 810 SE SWINNEY LANE PORTLAND ORE.
Drilling Machine Operator's License No. 57
[Signed] Robert L. Strasser
(Water Well Contractor)
Contractor's License No. 10 Date OCT 17, 1963