

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT AUG 20 1964 STATE ENGINEER (Please type or print)

MULT

001395

State Well No. IN/B-29 State Permit No.

(1) OWNER:

Name JOHN DEERE CO Address 2100 NE 181 ST AVE PORTLAND ORE

(2) LOCATION OF WELL:

County Mult Drillers well number 4174 1/4 SW 1/4 Section 29 T. 1N R. 3E W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [] Test Well [] Other [X]

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

12" Diam. from 0 ft. to 170 ft. Gage 330 10" Diam. from 166 ft. to 389 ft. Gage 279 16" Diam. from 0 ft. to 62.5 ft. Gage 375

(7) PERFORATIONS:

Perforated? [X] Yes [] No Type of perforator used STAR Size of perforations 3/8 in. by 1/4 in. 200 perforations from 122 ft. to 127 ft. 560 perforations from 150 ft. to 164 ft. 800 perforations from 187 ft. to 207 ft. 560 perforations from 228 ft. to 242 ft. 290 perforations from 248 ft. to 255 ft. 280 289 296

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. diam. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal-Material used in seal CEMENT GROUT Depth of seal 64 ft. Was a packer used? NO Diameter of well bore to bottom of seal 16 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [X] Yes [] No Type of water? SURFACE Depth of strata 35 FT. Method of sealing strata off CEMENT AND CASING

(10) WATER LEVELS:

Static level 114 ft. below land surface Date 8/7/64 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? [X] Yes [] No If yes, by whom? R.J. STRASSER Yield: 305 gal./min. with 140 ft. drawdown after 24 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 22 1/2 Was a chemical analysis made? [X] Yes [] No

(12) WELL LOG:

Diameter of well below casing Depth drilled 429 ft. Depth of completed well 389 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include LOOSE GRAVEL AND ROCK, GRAVEL AND BOULDERS, BROWN CLAY AND GRAVEL, RED CLAY, GRAVEL AND CLAY, LOOSE GRAVEL, CEMENTED GRAVEL, GRAVEL AND BOULDERS, SAND GRAVEL SOME SANDER, GRAVEL AND BOULDERS, GRAVEL AND GREY CLAY, SAND AND GRAVEL, GREY SILT, GREEN AND BROWN SHALE, SAND STONE, LIGHT BROWN CLAY.

Work started JUNE 23 1964 Completed AUG 18 1964 Date well drilling machine moved off of well AUG 12 1964

(13) PUMP:

Manufacturer's Name SUMO Type: SUBMERSIBLE H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R.J. STRASSER DRILLING CO (Person, firm or corporation) (Type or print) Address 8110 SE SUNSET LANE PORT. ORE Drilling Machine Operator's License No. 57 [Signed] Robert L. Strasser (Water Well Contractor) Contractor's License No. 10 Date AUG 19, 1964