

RECEIVED
MAR 2 1962

MULT
001399
G 2350

1N/3-29 D

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. _____

State Permit No. _____

(1) OWNER:

Name CEREGHINO BROTHERS

Address RT. 2 BOX 162 TROUTDALE, OREGON

(2) LOCATION OF WELL N.E. 185th & Sandy Blv

County MULTNOMAH Owner's number, if any—

1/4 1/4 Section 29 T. 1 N R. 3 E W.M.

Bearing and distance from section or subdivision corner (TL #55)

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

10 " Diam. from 0 ft. to 248.17 " ft. Gage 5/16

8 " Diam. from 239 ft. to 273 ft. Gage 5/16

" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS 10 "

Perforated? Yes No

Type of perforator used 1/4 way dr. down The 8 "

SIZE of perforations 2/8" x 1 1/2 in. by 1 1/2 x 6 ft in. Torch

96 perforations from 125 to 129 ft. to _____ ft.

168 perforations from 180 " 187 ft. to _____ ft.

120 perforations from 190 " 195 ft. to _____ ft.

perforations from _____ ft. to The 8 " ft.

132 perforations from the bottom to 22 ft. ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name _____

Type _____ Model No. _____

Slot size _____ Set from _____ ft. to _____ ft.

Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

Was a surface seal provided? Yes No To what depth? 34 ft.

Material used in seal— sand gravel and cement

Did any strata contain unusable water? Yes No

Type of water? _____ Depth of strata _____

Method of sealing strata off _____

(10) WATER LEVELS:

Static level 59 ft. below land surface Date _____

Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by: _____

[Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? BOTTNER DRILLING CO.

Yield: 365 gal./min. with 46 ft. drawdown after 1 hrs.

" 385 " " 49 " " 2 "

" 452 " " 57 " " 4 "

Pump test 555 gal./min. with 65 ft. drawdown after 5 hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water 52 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 10 inches.

Depth drilled 273 ft. Depth of completed well 273 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	4
Sandy Clay	4	8
Loose Gravel & Boulders	8	60
Yellow Clay & Gravel	60	111
Gravel	111	114
Cemented Gravel	114	126
Gravel (Water Bearing)	126	134
Yellow Sand	134	138
Cemented Gravel	138	179
Cemented Gravel & Sand	179	195
Gravel & Black sand (W.B.)	195	196
Cemented Gravel (Approx. 130 gpm)	196	211
Blue Clay	211	251
Black Rock	251	269*
Gravel Water Bearing	269	273

* From 260 to 269 Black Porous rock Water Bearing with unlimited supply
Crystal Clear and sand free

Work started Aug. 8 1961 Completed Oct. 11 1961

(13) PUMP:

Manufacturer's Name _____

Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME HAAKON BOTTNER DRILLING COMPANY

(Person, firm, or corporation) (Type or print)

Address 11544 N. E. GLISAN ST.

Driller's well number _____

[Signed] H. Bottner (Well Driller)

License No. 109 Date _____, 19____