

MULTI
001421

WELL REPORT
STATE OF OREGON

State Well No. IN/3-33D(1)

State Permit No. _____

(1) OWNER:

Name REYNOLDS HIGH SCHOOL
Address 1200 N.E. 201st Ave.
Trousdale, Oregon

SCHOOL DIST. NO. 7

NOV 18 1958

(2) LOCATION OF WELL:

County Multnomah Owner's number, if any _____

1/4 Section T. R. W.M.

Bearing and distance from section or subdivision corner

400 ft. north and 725 ft. east from the
S.W. corner of Dist. No 7 property, S.W. corner
located 613.18 ft north and 00.09 east
of S.E. corner of Wm. Taylor D L C

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

10 " Diam. from _____ ft. to 250 ft. Gage New
" Diam. from _____ ft. to _____ ft. Gage St. Blk
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Star 4 way drive down
SIZE of perforations 3/8 in. by 1 1/2 in.
504 perforations from 205 ft. to 226 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 30 ft.
Material used in seal— Cement, Sand & Gravel
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 90 ft. below land surface Date 12/4/57
Artesian pressure not artesian well _____ square inch Date _____

Log Accepted by: _____

[Signed] [Signature] Date Nov. 14, 1958 1958
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Bottner
Was a pump test made? Yes No If yes, by whom Well Drilling
Yield: 110 gal./min. with trial test ft. drawdown after 3 hrs.
" 150 " 74 " 6 "
" 180 " 80 " 6 1/2 "
Base test 220 gal./min. with 92 ft. drawdown after 6 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 10 inches.
Depth drilled 305 ft. Depth of completed well 308 1/2 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Boulders	0	10
Cemented Gravel with	9	40
Streak of Gravel Approx. GPM	40	42
Gray Clay	42	48
Cemented Gravel	48	105
Boulders	105	110
Cemented Gravel	110	205
Gravel (Water Bearing) *	205	226
Cemented Gravel	226	237
Blue Clay	237	268
Brown Clay w/ a little Gravel	268	295
Brown Loose Gravel	295	305
(WATER BEARING)		

NOTE:

Liner Installed, Standard Steel Pipe
8 inch x 60 ft. with bottom 10 ft.
Perf. Slots by Torch 3/16" x 6 inches
6 Perf. to a ft.
overlap 5 ft. (The 10 inch pipe
overlapping the 8
inch liner 5 Ft.)

Work started 10/9/57 19 _____ Completed 12/4 1957

(13) PUMP:

Manufacturer's Name Jacuzzi
Type: Oil Lubricated Turbine H.P. 20

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME HAAKON I. BOTTNER WELL DRILLING
(Person, firm, or corporation) (Type or print)

Address 11544 N. E. GLISAN ST. PORTLAND 26
PHONE AL3-3606

Driller's well number _____

[Signed] [Signature]
(Well Driller)

License No. 109 Date Oct. 3 1958