WATER WELL REPORT STATE OF OREGON

DEC 2 1983 State Well No.

PLEASE TYPE or PRINT IN INC. OREGON

(1) OWNER:	(10) LOCATION OF WELL:	•
Name Y.M.C.A Camp Collins	County Multnamah Driller's well	number
Address 3001 S. E. Oxbow Parkway	SE % SW % Section 10 T.1 N	R. 4 E W.M.
City Gresham, Oregon 97030 State	Tax Lot # Lot Blk	Subdivision
(2) TYPE OF WORK (check):	Address at well location:	
New Well Deepening □ Reconditioning □ Abandon □		
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	ell.
	Depth at which water was first found 320	ft
(3) TYPE OF WELL: (4) PROPOSED USE (check):		and surface. Date
Rotary Air M Driven 🗆 Domestic 🖫 Industrial 🗆 Municipal 🔇		er square inch. Date $12/7/83$
Receive Mud & Dug	(12) WELL LOG: Diameter of well below	casing 8"
(5) CASING INSTALLED: Steel X Plastic Threaded Welded X	Formation: Describe color, texture, grain size and structure of materials; and show	
8."Diam from * 1½ ft. to 308 ft. Gauge .250	thickness and nature of each stratum and aquifer pene	trated, with at least one entry
" Diam. from	for each change of formation. Report each change in and indicate principal water-bearing strata.	position of Static Water Level
LINER INSTALLED:	MATERIAL	D
"Diam from ft. to ft. Gauge	Gray ash flow - soft	From To SWL
	Gray ash flow - firm	0 33 87 -
(6) PERFORATIONS: Perforated? Yes No	Cemented gravels	87 137
Type of perforator used	Sticky gray clay	137 165
Size of perforations in.	Soft blue-gray silty clay	165 177
perforations from ft. to ft.	Sticky gray clay	177 186
perforations from ft. to ft.	Soft blue=gray clay	186 192
perforations from ft. to ft.	Sticky gray clay	192 217
(7) SCREENS: Well screen installed? Yes XXNo	Soft brown clay	217 258
Manufacturer's Name	Firm gray-black basalt	258 269
Type	Soft gray clay w/basalt frag=	
Diam. Slot Size Set from ft. to ft.	ments/occ. basalt streak	269 298
Diam. Slot Size Set from ft. to ft.	Firm gray-black basalt, occ.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	red_streaks	298 337
a nump test made? Yes X No If yes, by whom?	M6.	
75	WELL COMPLETED TO 335'	·
recid: / J gai./min. with 40 ft. drawdown after 2 hrs.		· · · · · · · · · · · · · · · · · · ·
Air test gal/min. with drill stem at ft. hrs.		
Bailer test gal/min. with ft. drawdown after hrs.		
sian flow 60 g.p.m.	the state of the s	
emperature of water 72° F Depth artesian flow encountered 320 ft.	Work started 11/18/83 19 Complete	- 12/7/92
		17.100
(9) CONSTRUCTION: Special standards: Yes □ No X Well seal—Material used	(unbonded) Water Well Constructor Certification (if applicable):	
Well sealed from land surface to 308 ft.		
Diameter of well bore to bottom of seal	This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.	
Diameter of well have below seel & in	[Signed]	
Number of sacks of cement used in well seal 25 sacks		
How was cement grout placed? 10sackspumpedtobot.tom.&.	Bonded Water Well Constructor Certification Bond 335-2912 Issued by Great Am	
pressured into annular 278 - 308 15 sacks + 5	(number) Surety Company Name	
el pumped into annular @ 50! back to surface.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
Was pump antalled be tween noType	Name A. M. JANNSEN WELL DRILLING CO. INC.	
Was a drive shoe used? Yes X No Plugs Size: location ft.	Name A. M. JANSEN WELL DRILLING CO. INC. (Person, firm or corporation) (Type or print)	
Did any strata contain unusable water?	Address 21075 SW Tualatin Valley Hwy. Aloha, CR	
type of water: depth of strata	[Signed Shew Me Marken	
Method of sealing strata off Was well gravel packed? □ Yes X No Size of gravel:	Water Well Constructor	
was well gravel packed? ☐ Yes K No Size of gravel: Gravel placed from	Size of gravel:	
parent at Oth springer and the U parent and the		