

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97301 within 30 days from the date of well completion.

WATER WELL REPORT

RECEIVED
JUN 27 1972
STATE ENGINEER
SALEM, OREGON

RECEIVED
AUG 25 1972

State Well No. 2117W-6
STATE ENGINEER
SALEM, OREGON
State Permit No. MULT 001556

(1) OWNER:

Name Jack (Mowrey) Mowrey
Address 6310 N. Amherst St.
Portland, Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 94 ft. Gage 1st.
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 4 ft. below land surface Date 6/12/72
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☐ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Bailer test 30 gal./min. with 4 ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(10) CONSTRUCTION:

Well seal—Material used Betonite
Depth of seal 30 ft.
Diameter of well bore to bottom of seal 9 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Multnomah Driller's well number
1/4 1/4 Section 2N R. 1W W.M.

Bearing and distance from section or subdivision corner

Section 6
195 ft from N.W. Corner - 20 ft from North side

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 94 ft. Depth of completed well 94 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Soil	0	5	
Soil- brown - sandy	5	30	
" blue - "	30	45	
clay - blue -	45	55	
sand - brown	55	60	
black- sand	60	70	
Sand - gray	70	80	
Clay - blue	80	88	
Gravel	88	94	

RECEIVED

JUN 14 1973

STATE ENGINEER
SALEM, OREGON

Work started June 5 1972 Completed June 12 1972

Date well drilling machine moved off of well June 20 1972

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Eugene V. Thompson Date June 26, 1972
(Drilling Machine Operator)

Drilling Machine Operator's License No. 217

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Barron & Strayer
(Person, firm or corporation) (Type or print)
7990 S.W. Sorrento Rd. Beaverton Ore. 97005
Address

[Signed] A. H. Barron
(Water Well Contractor)

Contractor's License No. 35 Date June 21, 1972