

RECEIVED  
SEP 18 1961

MULT  
001623

2N/1W-8N

STATE ENGINEER WELL REPORT  
SALEM, OREGON STATE OF OREGON

File Original and  
First Copy with the  
STATE ENGINEER,  
SALEM, OREGON

State Well No. ....

State Permit No. ....

(1) OWNER:

Name Pacific Coast Nursery  
Address Route 1, Box 111B  
Portland 10, Oregon

(2) LOCATION OF WELL:

County Multnomah Owner's number, if any—  
SW ¼ SW ¼ Section 8 T. 2N R. 1W W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
8" Diam. from 0 ft. to 106 ft. Gage Std.  
" Diam. from " ft. to " ft. Gage  
" Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used Mills Knife  
SIZE of perforations ¼ in. by 2 in.  
80 perforations from 85 ft. to 100 ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.

(8) SCREENS:

Well screen installed  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from " ft. to " ft.  
Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:

Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from " ft. to " ft.  
Was a surface seal provided?  Yes  No To what depth? " ft.  
Material used in seal—  
Did any strata contain unusable water?  Yes  No  
Type of water? Depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 38 ft. below land surface Date 5/12/61  
Artesian pressure lbs. per square inch Date

Log Accepted by

[Signed] *Jack M. Davis* Date *Aug 23*, 19*61*  
(Owner)

(11) WELL TESTS:

Drawdown is amount water level lowered below static level. *Wade*  
Was a pump test made?  Yes  No If yes, by whom? *Company*  
Yield: 85 gal./min. with 0 ft. drawdown after 1 hrs.  
" 300 " " 2 "  
" 460 " " 2 " 3 "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 51 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well 8 inches.  
Depth drilled 106 ft. Depth of completed well 106 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Fine brown sand	0	30
Fine grey sand	30	50
Brown packed sand	50	60
Grey sand (quicksand)	60	74
Loose sand & gravel (1" minus)	74	106

Work started 5/3/61 19. Completed 5/15/61 19

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME *Steinman Bros.*  
(Person, firm, or corporation) (Type or print)

Address *15112 S.E. McLoughlin, Milwaukie 22, Ore.*

Driller's well number *22-61*

[Signed] *Jack M. Davis*  
(Well Driller)

License No. *I* Date *5/19/61*, 19*61*