

(1) OWNER:
Name Pacific Coast State Engineer
Address 2244 N.E. Skidmore, SALEM, OREGON
Portland, Oregon 9572

(2) LOCATION OF WELL: Sawies Island
County Multnomah Owner's number, if any—
S.E. 1/4 S.E. 1/4 Section 17 T. 2 N R. 1 W ? W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check): Domestic Industrial Municipal
 Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded
8" Diam. from 0 ft. to 55' 6" ft. Gage # 280
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Is well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 8 ft.
Material used in seal— Drill cuttings
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 13 ft. below land surface Date 4/25/57
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] Master Halmar Date _____, 19____
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level. R.M. Wade Co
Was a pump test made? Yes No If yes, by whom? Portland
Yield: 200 gal./min. with 2 ft. drawdown after 2 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 8 inches.
Depth drilled 54 ft. Depth of completed well 54 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Silty brown sand	0	8
Grey quicksand	8	42
Sand and gravel	42	44
Gravel-6" down to pea gravel	44	54

Work started Mar. 20 1957 Completed Mar. 25 1957

(13) PUMP: Manufacturer's Name
Type: H.P.

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Steinman Bros. (Type or print)
(Person, firm, or corporation)
Address 15112 S.E. McLoughlin, Milwaukie, Or
Driller's well number 357
[Signed] R.E. McConnell (Well Driller)
License No. 1 Date April, 13, 1957