NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

MULT 002008

RECEIVED
MAY 15 1975
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 2N-2W-36
State Permit No.

(1) OWNER:
Name Ben Olson
Address Rte 2 Box 279 Portland, Oregon 97231

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [X] Driven [ ]
Cable [ ] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(5) CASING INSTALLED:
Threaded [ ] Welded [X]
6 " Diam. from 0 ft. to 169 ft. Gage .280
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? [ ] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
air " " "
Bailer test 9 gal./min. with 100 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 169 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 17 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? [ ] Yes [X] No Plugs Size; location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Mult. Driller's well number
¼ ¼ Section 36 T. 2-N R. 2-W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 161 trace ft.
Static level 600 ft. below land surface. Date 5-4-75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 720 ft. Depth of completed well 720 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top soil	0	2	
Yellow clay	2	20	
Brown clay	20	108	
Red clay	108	137	
Light brown clay	137	161	
Brown med. rock	161	195	
Blue med. rock	195	408	
Blue hard rock	408	535	
Blue med. rock	635	665	
Brown lava rock	665	668	
Blue med. rock	668	678	
Brown and black lava mixed	678	720	

Work started 4-29-75 19 Completed 5-4-75 19
Date well drilling machine moved off of well 5-4-75 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ralph Turner Date 5-13-75 19
(Drilling Machine Operator)
Drilling Machine Operator's License No. 254

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Ralph Turner Drilling Co. (Person, firm or corporation) (Type or print)
Address Rte 1 Box 141 Hillsboro, Oregon
[Signed] Ralph Turner (Water Well Contractor)
Contractor's License No. 247 Date 5-13-75, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119