

RECEIVED

APR 22 1985

MULT 002143

15/3E-8

STATE OF OREGON WATER WELL REPORT WATER RESOURCES DEPT SALEM, OREGON

(as required by ORS 537.765)

PLEASE TYPE OR PRINT IN INK

(for official use only)

(1) OWNER:

Name Memorial Baptist Church Address 4100 SE 182nd Ave City Cresham State ORE

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air [X] Driven [] Domestic [X] Industrial [] Municipal [] Thermal: [] Withdrawal [] Reinjection [] Cable [] Bored [] Piezometric [] Grounding [] Test []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Thermal: [] Withdrawal [] Reinjection [] Piezometric [] Grounding [] Test []

(5) CASING INSTALLED:

6" Diam. from 1 ft. to 100 ft. Gauge 2.50 Steel Threaded [X] Plastic Welded []

LINER INSTALLED:

4" PVC 85 125 200lb Steel Threaded [] Plastic Welded [X]

(6) PERFORATIONS:

Size of perforations 3AW in. by 1/8 - 6 in. 160 perforations from 85 ft. to 125 ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [X] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Air test 25 gal./min. with drill stem at 110 ft. 4 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes [] No [X] Well seal—Material used Cement Well sealed from land surface to 25 ft. Diameter of well bore to bottom of seal 10 in. Diameter of well bore below seal 6 in. Amount of sealing material 30 sacks [] pounds [X] How was cement grout placed? Poured Through 3" ID Pipe Was pump installed? Type HP Depth ft. Was a drive shoe used? [X] Yes [] No Plugs Size: location ft. Did any strata contain unusable water? [] Yes [X] No Type of Water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County MULT 1/4 1/4 of Section 8 of Township 15, Range 3E, WM. Tax Lot Lot Block Subdivision MAILING ADDRESS OF WELL (or nearest address) 4100 SE 182nd Cresham, ORE.

(11) WATER LEVEL OF COMPLETED WELL:

Depth at which water was first found 110 ft. Static level 60 ft. below land surface. Date Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6 Depth drilled 130 ft. Depth of completed well 125 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: TOP SOIL (0-2), Loose GRAVEL (2-15), Cemented SAND + GRAVEL (15-125), Lightly Cemented (125-60), Loose GRAVEL (125-130), Cemented casing + Hole (90 FT TO 105), Let Harden Drilled out.

Date work started 3-25 / completed 4-5 85 Date well drilling machine moved off of well 4-5 1985

(unbonded) Water Well Constructor Certification (if applicable): This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Date, 19

(bonded) Water Well Constructor Certification: Bond 2546611 Issued by: SAFE CO (number) (Surety Company Name) On behalf of Ted Pulliam well drilling (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

(Signed) Ted W Pulliam (Water Well Constructor) (Dated) 4-19-85

NOTICE TO WATER WELL CONSTRUCTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*46866-690