

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

MULT

002159

1/3-10

State Well No.

State Permit No.

(1) OWNER:

Name ST. HENRY'S PARRISH  
Address 347 NW. 1ST GRESHAM, ORE

(2) LOCATION OF WELL:

County CLATSOP Driller's well number 4160  
¼ Section T. R. W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well  Deepening  Reconditioning  Abandon   
 abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Rotary  Driven   
Irrigation  Test Well  Other  Cable  Jetted   
Dug  Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED: Threaded  Welded   
8" Diam. from 0 ft. to 349 ft. Gage 277  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used STAR  
Size of perforations 3/8 in. by 1 1/4 in.  
480 perforations from 320 ft. to 336 ft.  
450 perforations from 240 ft. to 258 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed  Yes  No  
Manufacturer's Name Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT GROUT  
Depth of seal 41 ft. Was a packer used?  
Diameter of well bore to bottom of seal 12 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? SURFACE Depth of strata 15  
Method of sealing strata off CASING AND CEMENT

(10) WATER LEVELS:

Static level 89 ft. below land surface Date 11/8/63  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? RJSTRASSER  
Yield: 183 gal./min. with 36 ft. drawdown after 6 hrs.  
" 160 " 31 " 1 "  
" 150 " 28 " 1 "  
Ballor test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 54.0 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing  
Depth drilled 349 ft. Depth of completed well 349 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>FILL</u>	<u>0</u>	<u>5</u>
<u>SILT AND CLAY</u>	<u>5</u>	<u>15</u>
<u>GRAVEL AND BOULDERS</u>	<u>15</u>	<u>30</u>
<u>CEMENTED GRAVEL</u>	<u>30</u>	<u>33</u>
<u>SAND</u>	<u>33</u>	<u>36</u>
<u>CEMENTED GRAVEL</u>	<u>36</u>	<u>117</u>
<u>GREY CLAY AND GRAVEL</u>	<u>117</u>	<u>163</u>
<u>CEMENTED GRAVEL</u>	<u>163</u>	<u>177</u>
<u>YELLOW CLAY</u>	<u>177</u>	<u>183</u>
<u>CEMENTED GRAVEL</u>	<u>183</u>	<u>240</u>
<u>SAND AND GRAVEL (WATER)</u>	<u>240</u>	<u>263</u>
<u>BROWN CLAY</u>	<u>263</u>	<u>292</u>
<u>GREEN SHALE</u>	<u>292</u>	<u>300</u>
<u>CEMENTED GRAVEL</u>	<u>300</u>	<u>323</u>
<u>SAND AND GRAVEL (WATER)</u>	<u>323</u>	<u>338</u>
<u>CEMENTED GRAVEL</u>	<u>338</u>	<u>349</u>

Work started SEPT 10 1963 Completed NOV 13 1963  
Date well drilling machine moved off of well NOV 14 1963

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R.J. STRASSER DRILLING CO  
(Person, firm or corporation) (Type or print)  
Address 8110 SE SUNSET LANE FERT 6, ORE.  
Drilling Machine Operator's License No. 190  
[Signed] Robert J. Strasser  
(Water Well Contractor)  
Contractor's License No. 10 Date NOV 14 1963