

RECEIVED

DEC 14 1959

STATE ENGINEER
SALEM OREGON

WATER WELL REPORT
STATE OF OREGON

MULT
002184

1/3-14C2

G1127

State Well No.

State Permit No.

G1046

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

(1) OWNER:

Name Melvin Gradin
Address Rt. 2, Gresham, Oregon

(2) LOCATION OF WELL:

County Mult Owner's number, if any—
1/4 1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 285 ft. Threaded Welded
Gage 33lb/ft
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used Star
SIZE of perforations 3/8 in. by 1 1/4 in.
20 perforations from 180 ft. to 197 ft.
20 perforations from 200 ft. to 216 ft.
20 perforations from 223 ft. to 229 ft.
40 perforations from 238 ft. to 240 ft.
40 perforations from 270 ft. to 278 ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 62 ft. below land surface Date
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Date, 19
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: 180 gal./min. with 214 ft. drawdown after hrs.
" " " "
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 10 inches.

Depth drilled 452 ft. Depth of completed well 282 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Clay	0	62
Cemented Gravel	62	81
Cemented Gravel & boulders	81	90
Clay and gravel	90	98
Cemented Gravel	98	104
Some boulders	104	115
Cemented Gravel	115	120
Some water	120	140
Tighter formation	140	179
Clay and gravel	179	185
Very tight formation	185	197
Large gravel with clay	197	223
Small amount of loose gravel	223	242
Hard boulders	242	250
Sticky brown clay	250	253
Clay and gravel	253	288
Clay very sticky	288	295
Blue clay with gravel	295	315
Brown clay with gravel	315	330
Blue clay with gravel	330	385
Shale	385	443
Cement plug at 285'		

Work started February 19 59 Completed June 1959

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. J. STRASSER DRILLING CO.
(Person, firm, or corporation) (Type or print)

Address 8110 S. E. Sunset Lane, Portland 6, Ore.

Driller's well number 4009

[Signed] Robert J. Strasser
(Well Driller)

License No. 10 Date Aug. 19, 1959