WATER WELL REPORT STATE OF OREGON

MULT 002281

RECEIVED 15

JAN5 1984

PLEASE TYPE or PIWATER NESOURCES DEPT. SALEM. OREGON

(1) OWNER:	(10) LOCATION OF WELL:
Name GARY WAUS	County MULTOMOMAH Driller's well number 553
Address 18601 SE CHELPELIN RO.	4 4 Section 20 T. 15 R. 3E W.M.
City PORTLAWO State OREGON	Tax I ot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location:
	18601 S.E. CHELDELIN, PORTLAND
New Well Deepening Reconditioning Abandon	(11) WATER LEVEL: Completed well.
If abandonment, describe material and procedure in Item 12.	Double to the second se
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 70 ft. below land surface. Date 12-14-
Rotary Air Driven Domestic Industrial Municipal	Artesian pressure lbs. per square inch. Date
Receive Mud □ Dug □ Irrigation ★ Test Well □ Other □ □ Bored □ Thermal: Withdrawal □ Reinjection □	
Bored Thermal: Withdrawal Reinjection	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel Plastic	Depth drilled 18 ft. Depth of completed well 185 ft.
6" Diam. from + 1	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry
	for each change of formation. Report each change in position of Static Water Level
"Diam. from	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
	TOP SOIL 0 1
(6) PERFORATIONS: Perforated? □ Yes No	BROWN CLAY 1 25
Type of perforator used	BLUE CLAY 25 43
Size of perforations in. by in.	SOFT BROWN ROCK 43 62
perforations from	BROWN CLAY 62 79
perforations from	CEMENTED GRAVEL 79 96
perforations fromft. toft.	CEMENTED GRAVEL
	AND BOULDERS 90 123
(7) SCREENS: Well screen installed? Yes \(\text{No} \)	CEMENTED GRAVEL 123 130
Manufacturer's Name JOHUSON	BLUE CLAY 130 143
Type STANLESS STEEL Model No.	CEMENTED GRAVEL 43 177
Diam. Slot Size 50. Set from 1.60. ft. to 165 ft.	LOOSE SAND AND
Diam. 5. Slot Size So. Set from 175 ft. to 180 ft.	SOME GRAVEL 177 184 70
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	COMENTED GRAVEL 184 187
The manufacture de 2 of Mar. 10 . 1 . 1 . 2	
a pump test made?	
Treid: gal./min. with ft. drawdown after hrs. " " " " "	
Air test gal./min. with drill stem at ft. hrs.	
M	
	Work started 11-23 19 83 Completed 12-14 1983
(9) CONSTRUCTION: Special standards: Yes \(\text{No.} \)	Date well drilling machine moved off of well 2-14 19 83
Well seal—Material used CEMENT - 3% BEUTONITE	(unbonded) Water Well Constructor Certification (if applicable):
Well sealed from land surface toft.	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of seal	and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal in.	[Signed] Date 12-30, 1983
Number of sacks of cement used in well seal sacks	Bonded Water Well Constructor Certification:
How was cement grout placed? PUMPED, ADDITIONAL	Bond FB 20219 Issued by: ORFSOW AUTO
135 - 5 SAEKS COMPAIN USED	(number) Surety Company Name This well was drilled under my jurisdiction and this report is true to
135 - 3 ARKS CEMENT USED	the best of my knowledge and belief.
Was pump installed?	Name Kaler War Dhung Co.
Was a drive shoe used? Yes □ No Plugs Size: location ft. Did any strata contain unusable water? □ Yes ☒ No	Address 63 50 SE BROWNEE MILWAUKE
Type of Water? depth of strata	OON A
Method of sealing strata off	[Signed]
	Water Well Constructor
Was well gravel packed? ☐ Yes SNo Size of gravel:	