NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUN 6 - 1972 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

MULT 002327

State Well No. 1/3-22

State Permit No. G-6370

(1) OWNER:
Name Frank Newell
Address 2160 NE Hoyt Dr. Gresham, Oreg

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 273 ft. Gage .250
5 1/4" Diam. from 268 ft. to 341 ft. Gage .188
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Torch cut
Size of perforations 1/4 in. by 10 in.
164 perforations from 273 ft. to 341 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test 30 gal./min. with 15 ft. drawdown after 2 hrs.
Artesian flow — g.p.m. —
Temperature of water 53 Depth artesian flow encountered — ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 145 ft.
Diameter of well bore to bottom of seal 8 in.
Diameter of well bore below seal driven 6" pipe
Number of sacks of cement used in well seal 2 sacks
Number of sacks of bentonite used in well seal 1 sacks
Brand name of bentonite National
Number of pounds of bentonite per 100 gallons of water mixed with drill cuttings lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? — depth of strata —
Method of sealing strata off —
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from — ft. to — ft.

(10) LOCATION OF WELL:
County Mult. Driller's well number
1/4 1/4 Section 22 T. 1S R. 3E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found ft.
Static level 168 ft. below land surface. Date Sept 10
Artesian pressure — lbs. per square inch. Date —

(12) WELL LOG: Diameter of well below casing to bottom
Depth drilled 341 ft. Depth of completed well 339 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Multi colored clay	0	38	
Soft rock	38	46	
Hard laud 1" hr.	46	52	
red volcanic ash	52	77	
black ash	77	98	
hard laud 1" hr.	98	117	
soft stone	117	149	
brown silt	149	151	
cement gravel	151	211	
Sand stone	211	230	
lightly cemented gravel	230	245	
cement gravel	245	263	
yellow clay	263	273	
yellow sand stone	273	286	
black clay	286	290	
sandstone varing colors with water	290	341	168
5 H.P. Red jacket set to April '72	231'		

Work started Aug 23 1971 Completed Sept 10 1971
Date well drilling machine moved off of well Sept 10 1971

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] [illegible] (Drilling Machine Operator) Date April 1, 1972
Drilling Machine Operator's License No. 596

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name H. O. Olsen (Person, firm or corporation) (Type or print)
Address 1851 SE Powell Gresham
[Signed] H. O. Olsen (Water Well Contractor)
Contractor's License No. 282 Date April 30, 1972

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119