

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

RECEIVED

WATER WELL REPORT

MULT
002418

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion

APR 8 1980

STATE OF OREGON
(Please type or print)

State Well No. 1s/3E-27 da

State Permit No.

WATER RESOURCES DEPT
SALEM, OREGON

(1) OWNER:

Name City of Wood Village
Address Multnomah County, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

12" Diam. from 0 ft. to 200 ft. Gage 375
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Johnson
Type stainless steel Model No.
Diam. 10P Slot size .250 Set from 200 ft. to 230 ft.
Diam. 10P Slot size .250 Set from 245 ft. to 255 ft.
10P .250 270 280

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made Yes No. If yes, by whom? Aqua Pump
d: 250 gal./min. with 20 ft. drawdown after 1/2 hrs.
350 " 26 " 3/2 "
" 500 " 57 " 24 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used cement
Well sealed from land surface to 22 inch 25 feet ft.
Diameter of well bore to bottom of seal 16 inch 25 feet ft.
Diameter of well bore below seal 12 in. & 16 in.
Number of sacks of cement used in well seal 58 sacks
How was cement grout placed? pressure pumped

Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Multnomah Driller's well number D 280-80
N E 1/4 S E 1/4 Section 27 T. 1S R. 3E W.M.

Bearing and distance from section or subdivision corner
1510 feet N. 1290 feet W of SE corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 15 ft.
Static level 98 ft. below land surface. Date 4/8/80
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12
Depth drilled 300 ft. Depth of completed well 300 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
topsoil	0	2	
clay brown & sandy	2	14	
gravel water bearing	14	16	
gravel cemented	16	28	
gravel, sand boulders	28	60	
gravel & sand cemented	60	110	
sand & gravel	110	135	
gravel & sand water/b	135	230	
sand brown water bearing	230	245	
gravel & sand water/b	245	257	
sand brown fine	257	270	
claystone gray water/b	270	285	
clay gray	285	300	

Work started 1/3/80 19 Completed 3/28/80 19
Date well drilling machine moved off of well 4/8/80 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] *Dwan Brown* Date 4/8/80, 19.
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1306

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name S & M Drilling & Supply Inc.
(Person, firm or corporation) (Type or print)

Address 399 S E Walnut Canby, Ore 97013

[Signed] *Walter Mac*
(Water Well Contractor)

Contractor's License No. 497 Date 4/8/80, 19.