

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

RECEIVED
WATER WELL REPORT
MAR 27 1980 STATE OF OREGON
WATER RESOURCES DEPT. SALEM, OREGON
WATER RESOURCES DEPT. SALEM, OREGON
(Do not write above this line)

Should read 15/46-15 per
Kent Barnes phone call
3/16/80
State Well No. 1579E-15
State Permit No.

002519

(1) OWNER:
Name Moller's Nursery Inc.
Address R.T. 2 Box 535
Gresham, Oregon

(10) LOCATION OF WELL:
County Mult. Driller's well number
SW 1/4 SW 1/4 Section 15 T. 1S R. 1E W.M.
Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary Driven Domestic Industrial Municipal
Cable Jetted Irrigation Test Well Other
 Bored

(5) CASING INSTALLED:
10" Diam. from 63 ft. to 410 ft. Gage .250
8" Diam. from 380 ft. to 520 ft. Gage .250

(6) PERFORATIONS:
Perforated? Yes No.
Type of perforator used torch
Size of perforations 6 in. by 1/8 in.
400 perforations from 410 ft. to 520 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:
Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Ted
250 gal./min. with 70 ft. drawdown after 8 hrs.
235 " " 60 " " 2 "
250 " " 70 " " 6 "
Bailer test none gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water 59 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:
Well seal—Material used Cement 4% Bent.
Well sealed from land surface to 360 ft.
Diameter of well bore to bottom of seal 14 - 12 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 79 sacks
How was cement grout placed? Grout Pumped

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) WATER LEVEL: Completed well.
Depth at which water was first found 29 ft.
Static level 410 ft. below land surface. Date 3/1/80
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG: Diameter of well below casing none
Depth drilled 525 ft. Depth of completed well 520 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
red clay	0	13	
brown clay&sand	13	23	
grayclay & sand	23	29	8
gray clay & gravel&boulder	29	36	
brown clay & boulders	36	47	
brown clay & sand	47	54	
cemented gravel	54	79	
brown clay & boulders	79	96	
cemented gravel	96	112	
gray clay & gravel	112	122	
gray clay stone	122	135	
brown clay & gravel	135	186	
brown clay & sand	186	208	
brown clay & gravel	208	232	
brown sandstone	232	286	
brown retten rock	286	297	
cemented gravel	297	315	
brown clay	315	332	105
blue clay & sand	332	337	125

Work started 10/16 1979 Completed 3/17 1980
Date well drilling machine moved off of well 3/17 1980

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Nick Smith Date 3/17/80
(Drilling Machine Operator)
Drilling Machine Operator's License No. 882

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Ted Pulliam Well Drilling
(Person, firm or corporation) (Type or print)
Address 18211 S.E. Powell, Gresham, Ore.
[Signed] Ted W Pulliam
(Water Well Contractor)
Contractor's License No. 616 Date 3/17, 1980

