

RECEIVED JUN 6 1960

MULT 002591

74-21F1

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT STATE OF OREGON

State Well No. No. G 1261

(1) OWNER:

Name SGENIC FRUIT COMPANY  
Address RT. 2 - BOX 392  
GRESHAM, OREGON

(2) LOCATION OF WELL:

County MULTNOMAH Owner's number, if any—  
SE 1/4 NW 1/4 Section 21 T. 1 S R. 4 E W.M.  
Bearing and distance from section or subdivision corner 80 Ft. N.  
and 1180 Ft. W. from the 1/4 corner of Center  
of Section 21, within SE 1/4, NW 1/4 of Section 21  
100' S & 100' E of Dodge Park and Altman Road.

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

8" Diam. from surface 260 ft. to 27 lb/ft. Gage 27 lb/ft.  
6" Diam. from 255 ft. to 480 ft. Gage 19 lb/ft.  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used Star  
SIZE of perforations 3/8 in. by 1 1/4 in.  
360 perforations from 241 ft. to 250 ft.  
320 perforations from 450 ft. to 463 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) Legal:

Mar 80 FT N & 1180 FT  
TYE W FROM 1/4 CORNER,  
DI CENTER OF SECTION  
21\*  
Gravel placed from \_\_\_\_\_ ft.  
Installed  Yes  No  
Model No. \_\_\_\_\_  
ft. to \_\_\_\_\_ ft.  
ft. to \_\_\_\_\_ ft.

Gravel placed from \_\_\_\_\_ ft.

Was a surface seal provided?  Yes  No To what depth? 80 ft.  
Material used in seal— Neat cement grout  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:

Static level 190 ft. below land surface Date Dec. 5, 1959  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Log Accepted by: Scenic Fruit Co.  
[Signed] By Audrey Landwehr Date June 3, 1960  
(Owner) Memo.

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? Strasser  
Yield: 85 gal./min. with 62 ft. drawdown after 8 hrs.  
" 74 " " 57 " " "  
" " " " " "  
Bailer test gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well \_\_\_\_\_ inches.

Depth drilled 480 ft. Depth of completed well 480 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP-SOIL	0	3
Clay	3	56
Clay	53	63
Boulders and Clay	63	76
Cement Gravel	76	80
Cement Gravel	80	86
Gravel with clay binder	86	100
Gravel falling in	100	190
Gravel	193	204
Soft Mud	204	208
Cement Gravel	208	244
Gravel, some sand with water	244	250
Clay	250	270
Gravel and clay	270	354
Packed sand	354	393
Clay	393	425
Gravel	425	450
Water bearing porous sandstone	450	463
Sandstone	463	480

Work started March 28 1959. Completed December 1959

(13) PUMP:

Manufacturer's Name JACUZZI  
Type: TURBINE H.P. 10

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. J. STRASSER DRILLING CO.  
(Person, firm, or corporation) (Type or print)

Address 8110 S.E. Sunset Lane, Portland 6, Ore.

Driller's well number 10 4014

[Signed] Robert J. Strasser  
(Well Driller)

License No. 10 Date Feb. 4, 1960