MULT 2644 RECEIVED

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

MULT 002644

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

MAR 25 1974
STATE ENGINEER
SALEM, OREGON

State Well No. 1S/5E-18
State Permit No.

Mult

(1) OWNER:
Name George Pulliam
Address Rt 1 Box 310 Troutdale, Oreg.

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 22 ft. Gage 250#
5" Diam. from 0 ft. to 108 ft. Gage 125#
PLUG
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Saw cut
Size of perforations 1/8 in. by 8 in.
120 perforations from 56 ft. to 106 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
ld: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 10 gal./min. with 40 ft. drawdown after 2 hrs.
esian flow g.p.m.
perature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used cement
Well sealed from land surface to 45' ft.
Diameter of well bore to bottom of seal 8 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 1 sacks
Number of sacks of bentonite used in well seal 1 sacks
Brand name of bentonite National
Number of pounds of bentonite per 100 gallons of water Mixed with clay slurry lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☒ Yes ☐ No Size of gravel: 1/2" rings
Gravel placed from 45 ft. to 107 ft.

(10) LOCATION OF WELL:
County Clackamas Driller's well number
¼ ¼ Section 18 T. 1S R. 5E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found ft.
Static level 46' ft. below land surface. Date
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing to bottom
Depth drilled 108 ft. Depth of completed well 108 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top soil	0	2	
clay & rock	2	40	
soft rock 4 gal.	40	80	46
Volcanic ash	80	90	46
with water 6 g.p.m.			
red rock	90	105	

Work started Sept 27 1974 Completed Oct 3 1974
Date well drilling machine moved off of well Oct 3 1974

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] A. O. Olsen (Drilling Machine Operator) Date Nov, 1974
Drilling Machine Operator's License No. 214

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name A.O. Olsen Well Drilling Inc. (Person, firm or corporation) (Type or print)
Address 18211 SE Powell Gresham
[Signed] A. O. Olsen (Water Well Contractor)
Contractor's License No. 282 Date Nov, 1974

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119