

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

170W

MULT

2711

WATER WELL REPORT

State Well No. 11-2 B

State Permit No. G3028

RECEIVED FEB 3 1965

(1) OWNER:

Name **STATE ENGINEER**
PACIFIC NORTHWEST ORE. BELL
 Address **421 SW OAK ST.**
PORTLAND, ORE

(2) LOCATION OF WELL:

County **MULT.** Driller's well number **4783**
 NW 1/4 NE 1/4 Section **2** T. **15** R. **1E** W.M.
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
 8" Diam. from **0** ft. to **212** ft. Gage **277**
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used **STAR**
 Size of perforations **3/8** in. by **1 1/4** in.
120 perforations from **165** ft. to **171** ft.
200 perforations from **175** ft. to **185** ft.
140 perforations from **193** ft. to **200** ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal **CEMENT GROUT**
 Depth of seal **56** ft. Was a packer used? **No**
 Diameter of well bore to bottom of seal **12** in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level **70** ft. below land surface Date **1/15/65**
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? **RJ STRASSER DRILLING CO**
 Yield: **170** gal./min. with **70** ft. drawdown after **8** hrs.
 " **117** " " **54** " " **1** "
 " **84** " " **44** " " **1** "
 Bailor test gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water **53 1/2** Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
 Depth drilled **225** ft. Depth of completed well **212** ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	15
SANDY CLAY	15	48
CEMENTED GRAVEL	48	72
SAND AND GRAVEL	72	88
CEMENTED GRAVEL	88	150
SAND AND GRAVEL SOME CLAY	150	270
LARGE LOOSE GRAVEL	170	183
CEMENTED GRAVEL	183	212
BROWN SAND	212	225

Work started **DEC 11 1964** Completed **JAN 19 1965**
 Date well drilling machine moved off of well **JAN 15 1965**

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME **RJ. STRASSER DRILLING CO**
 (Person, firm or corporation) (Type or print)

Address **8110 SE SUNSET LANE PORTLAND**

Drilling Machine Operator's License No. **190**

[Signed] **Robert J. Strasser**
 (Water Well Contractor)

Contractor's License No. **10** Date **FEB**