

RECEIVED

DEC 2 1960

MULT

2717

WATER WELL REGIONAL

State Well No. 1/1-3J(1)

STATE ENGINEER

STATE OF OREGON

61851

State Permit No.

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

(1) OWNER:

Name Eastside Plating Works
Address 310 SE Stephens
Portland, Oregon

(2) LOCATION OF WELL:

County Multnomah Owner's number, if any 1
Bearing and distance from section or subdivision corner

310 Stephens St. approximately 65' E. of S.E. 3rd Ave adjacent to Lot 1, Block 45 Stephens Add. Then to East Portland.

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic [] Industrial [X] Municipal []
Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from surf. ft. to 180 ft. Gage 27 #/ft.
Threaded [] Welded [X]

(7) PERFORATIONS:

Perforated? [X] Yes [] No
Type of perforator used
SIZE of perforations 3/8 in. by 1 1/4 in.
360 perforations from 158 ft. to 170 ft.

(8) SCREENS:

Well screen installed [] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? [] Yes [X] No To what depth? ft.
Material used in seal-
Did any strata contain unusable water? [] Yes [X] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 53 ft. below land surface Date Sept 27, 60
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] [Signature] Date 12/11/1960 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom?
Yield: 100 gal./min. with 3.5 ft. drawdown after 6 hrs.
150 " 7 " 6 "
200 " 12 " 6 "

(12) WELL LOG:

Diameter of well 8 inches.
Depth drilled 180 ft. Depth of completed well 180 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Sand and silt, Gravel and boulders, Brown sand, Loose gravel and sand, Cemented gravel, etc.

Work started Sept. 1 1960. Completed Sept. 28 1960

(13) PUMP:

Manufacturer's Name Johnston
Type: Submersible H.P. 7 1/2

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. J. Strasser Drilling Co.
Address 8110 SE Sunset Lane, Portland 6, Oreg.

Driller's well number 4102
[Signed] Robert J. Strasser (Well Driller)

License No. 10 Date Oct. 1, 1960