

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

Data from well

WATER WELL REPORT

MULTI 2729

State Well No. 1/1-3D(4)

Registration No. GR-2950 STATE OF OREGON

State Permit No.

(1) OWNER:

Name Pacific First Federal Savings & Loan Assn. Address 801 6th Ave. Portland, Oregon

(2) LOCATION OF WELL:

County Multnomah Owner's number, if any-- NW 1/4 NW 1/4 Section 3 T. 1 S. R. 1 E W.M. Bearing and distance from section or subdivision corner Lots 1 & 2, Block 180 elevation 58

(3) TYPE OF WORK (check):

New Well [] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic [] Industrial [x] Municipal [] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

14" Diam. from 10 ft. to 264 ft. Gage Threaded [] Welded []

(7) PERFORATIONS:

Perforated? [x] Yes [] No Type of perforator used SIZE of perforations in. by in. perforations from 230 ft. to 237 ft.

(8) SCREENS:

Well screen installed [] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [] Yes [] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [] Yes [] No To what depth? ft. Material used in seal-- Did any strata contain unusable water? [] Yes [] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 48 ft. below land surface Date 1955 Artesian pressure lbs. per square inch Date Log Accepted by: [Signed] Date 19 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [] No If yes, by whom? Yield: 500 gal./min. with 140 ft. drawdown after hrs. 700 96 Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well 14 inches. Depth drilled 368 ft. Depth of completed well ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include soil and fill, sand, brown packed, gravel, cemented, sand and gravel, water bearing, gravel, cemented, clay, brown, sandy, sand and gravel, blue clay binder, sand & gravel, blue clay binder some water, gravel, cemented, sand and gravel, blue clay binder, possible water, sand and gravel, tight blue clay binder, sand and gravel, loose, good water, bearing formation, blue clay, scattered gravel, clay, brown, shale, hard, green, clay, brown & scattered green shale, shale, hard brown, clay, brown, sandstone brown & gray, brown clay, scatter scab basalt, basalt, gray. Work started 19 Completed 19

(13) PUMP:

Manufacturer's Name Worthington Corp. Type Turbine H.P. 25

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME (Person, firm, or corporation) (Type or print) Address Driller's well number [Signed] (Well Driller) License No. Date 19

STATE ENGINEER
Salem, Oregon

State Well No. 11-3D4

County Multnomah

Application No. _____

Water Level Record

OWNER: Pacific 1st Federal Savings OWNER'S NO. _____

Description of measuring point: _____

Electrical Conductivity in Micromhos at 25°C

Date	Water Level Feet (above below) Land Surface	Remarks	Date	Water Level Feet (above) (below) Land Surface	Remarks
<u>6-1-61</u>	<u>770</u>	<u>WSB</u>			
<u>7-18-61</u>	<u>904</u>	<u>WSB</u>			
<u>10-12-61</u>	<u>930</u>	<u>WSB</u>			

REMARKS: _____

Water Level Record

OWNER: Pacific 1st Fedral Savings & Loan OWNER'S NO. _____

Description of measuring point: Lip of port pipe on east side of well - 10.3 feet below L.S.D.

Date	Water Level Feet (above) (below) Land Surface	Remarks	Date	Water Level Feet (above) (below) Land Surface	Remarks
<u>2/24/61</u>	<u>74°</u>	<u>Airline Meas. WSB (Pumping)</u>			
<u>4/18/61</u>	<u>55.63</u>	<u>WSB static</u>			
<u>6-1-61</u>	<u>—</u>	<u>Pumping 59½° F - 81½° F</u>			
<u>7-18-61</u>	<u>—</u>	<u>" " "</u>			
<u>10-12-61</u>		<u>60° F.</u>			
<u>1-5-62</u>	<u>55.76</u>	<u>WSB STATIC</u>			

REMARKS: _____

