

MULT 2738

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

Record from WATER WELL REPORT

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

Well Registration STATE OF OREGON GR. 3903 (Please type or print)

State Well No. 1/1-3 E(4) Certificate # G.R. 3383

(1) OWNER:

Name Boiler Maker's Association Address 1313 SW 3 rd Avenue Portland

(2) LOCATION OF WELL:

County Multnomah Driller's well number SW 1/4 NW 1/4 Section 3 T. 1 S. R. 1 E. W.M. Bearing and distance from section or subdivision corner about 1900' S. & 1200' E. from the NW corner of Section 3

Owner: Joseph H. Anderson

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other Air Conditioning

(5) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 151 ft. Gage Threaded Welded

(7) PERFORATIONS:

Perforated? Yes No Type of perforator used Size of perforations in. by in. perforations from 120 ft. to 126 ft. perforations from 128 ft. to 140 ft.

(8) SCREENS:

Well screen installed Yes No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal-Material used in seal Depth of seal ft. Was a packer used? Diameter of well bore to bottom of seal in. Were any loose strata cemented off? Yes No Depth Was a drive shoe used? Yes No Was well gravel packed? Yes No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? Yes No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 56 ft. below land surface Date July 1942 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? Yes No If yes, by whom? Yield: 200 gal./min. with 27 ft. drawdown after 10 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 57 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing Depth drilled 151 ft. Depth of completed well 151 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include Clay, sandy; Gravel, cemented; Sand, Water bearing; Clay & gravel; Gravel, cemented; Sand & gravel - water bearing; Gravel & fine sand.

Work started 19 Completed July 19 42 Date well drilling machine moved off of well July 18, 1942

(13) PUMP:

Sterling Manufacturer's Name Type: Turbine (200 gpm) H.P. 20

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

R. J. Strasser NAME (Person, firm or corporation) (Type or print)

Address Drilling Machine Operator's License No.

[Signed] (Water Well Contractor)

Contractor's License No. Date, 19

