

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM 10, OREGON
within 30 days from the date
of well completion.

RECEIVED
JUL 2 1963
STATE ENGINEER

WATER WELL REPORT
(Please type or print)

MULT
02739
G2571

State Well No. 11-3E(5)
State Permit No. G 2380

(1) OWNER:
Name EQUITABLE SAVINGS AND LOAN
Address EQUITABLE BUILDING
PORTLAND, ORE.

(2) LOCATION OF WELL:
County MULT Driller's well number 4152
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED: Threaded Welded
16" Diam. from 0 ft. to 221 ft. Gage 312

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used STAR
Size of perforations 3/8 in. by 1/4 in.
180 perforations from 212 ft. to 217 ft.
240 perforations from 194 ft. to 204 ft.

(8) SCREENS: Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION: Well seal—Material used in seal CEMENT GROUT
Depth of seal 40 ft. Was a packer used? No
Diameter of well bore to bottom of seal 20 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 91 ft. below land surface Date 6/22/63
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? STRASSER
Yield: 570 gal./min. with 98 ft. drawdown after 8 hrs.
" 405 " 78 " 1 "
" 325 " 59 " 1 "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 55 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 16
Depth drilled 228 ft. Depth of completed well 228 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL | FROM | TO |
|-----------------------------|------|-----|
| BROWN CLAY | 0 | 11 |
| CLAY AND SAND | 11 | 30 |
| GRAY SAND | 30 | 50 |
| GRAVEL | 50 | 78 |
| LARGE GRAVEL AND COBBLES | 78 | 83 |
| GRAVEL, CLAY BINDER | 83 | 95 |
| CEMENTED GRAVEL | 95 | 134 |
| SAND AND GRAVEL SOME CLAY | 134 | 145 |
| LARGE GRAVEL | 145 | 168 |
| CEMENTED GRAVEL | 168 | 183 |
| BLACK SAND | 183 | 186 |
| WATER BEARING SAND + GRAVEL | 186 | 204 |
| GRAVEL, CLAY BINDER | 204 | 209 |
| BLACK SAND | 209 | 211 |
| WATER GRAVEL AND SAND | 211 | 219 |
| ROCK | 219 | 228 |

Work started MAY 23 1963 Completed JUNE 25 1963
Date well drilling machine moved off of well JUNE 25 1963

(13) PUMP: Manufacturer's Name _____ Type: _____ H.P. _____

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME RJ STRASSER DRILLING CO.
(Person, firm or corporation) (Type or print)
Address 810 SE SUNSET LANE
PORTLAND 6, ORE
Drilling Machine Operator's License No. 57
[Signed] Robert L. Strasser
(Water Well Contractor)
Contractor's License No. 10 Date JULY 6, 1963