

RECEIVED

DEC 22 1965

MULT 2740

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE ENGINEER STATE OF OREGON (Please type or print)

State Well No. 1/1-3 E(6)
State Permit No.

(1) OWNER:

Name PORTLAND STATE COLLEGE
Address 724 S.W. HARRISON PORTLAND, ORE.

(2) LOCATION OF WELL:

County MULT. Driller's well number 4215
SW 1/4 NW 1/4 Section 3 T. 15 R. 1E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [] Test Well [X] Other []
Rotary [] Cable [X] Dug []
Driven [] Jetted [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED:

12" Diam. from 0 ft. to 100 ft. Gage 330
12" Diam. from 172 ft. to 188 ft. Gage 330
12" Diam. from 196 ft. to 210 ft. Gage 330
Threaded [] Welded [X]

(7) PERFORATIONS:

Perforated? [] Yes [X] No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [X] Yes [] No

Manufacturer's Name EDWARD E. JOHNSON
STAINLESS STEEL Model No.
12" Slot size 60 Set from 160 ft. to 172 ft.
Diam. 12" Slot size 60 Set from 188 ft. to 196 ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT
Depth of seal 20 ft. Was a packer used? YES
Diameter of well bore to bottom of seal 20 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [] Yes [X] No
Was well gravel packed? [X] Yes [] No Size of gravel: 3/8 - 1/8
Gravel placed from 125 ft. to 210 ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 144 ft. below land surface Date 11/18/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? STRASSER
Yield: 510 gal./min. with 24 ft. drawdown after 8 hrs.
" 365 " " 16 " " 2 "
" 218 " " 10 " " 2 "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 54 Was a chemical analysis made? [X] Yes [] No

(12) WELL LOG:

Diameter of well below casing

Depth drilled 230 ft. Depth of completed well 210 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include BASEMENT, HARD PACKED SAND AND SILT, SANDY SILT, CEMENTED GRAVEL, SAND AND GRAVEL (TIGHT), SAND AND GRAVEL (LOOSE), CEMENTED GRAVEL, SAND AND GRAVEL, SAND, GRAVEL AND CLAY, SHALE AND BOULDERS, BROWN ROCK.

Work started MAY 11, 1964 Completed NOV 24, 1965
Date well drilling machine moved off of well NOV 24, 1965

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R.J. STRASSER DRILLING CO. (Person, firm or corporation) (Type or print)
Address 8110 SE SUNSET LANE PORTLAND, ORE.
Drilling Machine Operator's License No. 54
[Signed] Robert L. Strasser (Water Well Contractor)
Contractor's License No. 10 Date DEC 20, 1965