

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

SEP 15 1965

WATER WELL REPORT

2745

State Well No. 111-3M(3)

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

STATE ENGINEER SALEM OREGON

STATE OF OREGON

(Please type or print)

State Permit No.

(1) OWNER:

Name CITY OF PORTLAND
Address ROOM 209 CITY HALL PORTLAND, ORE

(2) LOCATION OF WELL: PUBLIC AUDITORIUM

County MULT. Driller's well number 4205
M.W. 5W1/4 Section 3 T. 15 R. 1E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
andonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [X]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(6) CASING INSTALLED:

Threaded [ ] Welded [X]
12" Diam. from 0 ft. to 317 ft. Gage 330
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [X] Yes [ ] No

Type of perforator used STAR
Size of perforations 3/8 in. by 1 1/4 in.
670 perforations from 205 ft. to 221 ft.
320 perforations from 246 ft. to 264 ft.
40 perforations from 293 ft. to 299 ft.

(8) SCREENS:

Well screen installed? [ ] Yes [X] No

Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT GROUT
Depth of seal 32 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? [ ] Yes [X] No Depth
Was a drive shoe used? [X] Yes [ ] No
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusuable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 84 ft. below land surface Date 8/28/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [ ] No If yes, by whom? STRASSER
Yield: 600 gal./min. with 90 ft. drawdown after 8 hrs.
" 380 " 54 " " "
" 240 " 36 " " " "

Ballor test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 56° Was a chemical analysis made? [X] Yes [ ] No

(12) WELL LOG:

Diameter of well below casing 12

Depth drilled 361 ft. Depth of completed well 317 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include: LOOSE GRAVEL, BROWN SAND AND BINDER SAND, GRAVEL AND CLAY, LOOSE SAND AND GRAVEL, SAND AND GRAVEL SOME CLAY, LOOSE SAND AND GRAVEL, GRAVEL AND SANDY CLAY, LOOSE SAND AND GRAVEL, GRAVEL SANDS AND CLAY, FINE BROWN SAND AND GRAVEL, GRAVEL, DARK GREY BINDER, COARSE SAND STONE, LOOSE SAND AND GRAVEL, LARGE GRAVEL AND SILT, STICKY GREEN CLAY, SAND AND GRAVEL, BROWN SANDY CLAY, SAND AND GRAVEL, SAND GRAVEL AND CLAY, BROWN CLAY, GREEN CLAY, WEATHERED ROCK.

Work started JULY 8 1965 Completed AUG 31 1965

Date well drilling machine moved off of well AUG 31 1965

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R.J. STRASSER DRILLING Co
(Person, firm or corporation) (Type or print)

Address 8110 SE SUNSET LANE PORTLAND, ORE

Drilling Machine Operator's License No. 54

[Signed] Robert L. Strasser
(Water Well Contractor)

Contractor's License No. 10 Date 7/13 1965