

MULT

WATER WELL REPORT

Well No. 1/1-4 (A)

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

Record from well Registration No. GR-2676

STATE OF OREGON

State Permit No. GR-2047

(1) OWNER:

Name Portland Art Assoc. Address Portland 5, Oregon

(2) LOCATION OF WELL:

County Multnomah Owner's number, if any-- NE 1/4 NE 1/4 Section 4 T. 1 S R. 1 E W.M. Block 223 Portland 1200' S. & 400' W. elevation 1245

(3) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic [ ] Industrial [X] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [ ] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 113 ft. Gage ...

(7) PERFORATIONS:

Perforated? [ ] Yes [ ] No Type of perforator used SIZE of perforations in. by in. perforations from 79 ft. to 109 ft.

(8) SCREENS:

Well screen installed [ ] Yes [ ] No Manufacturer's Name Type Model No. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [ ] Yes [ ] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [ ] Yes [ ] No To what depth? ft. Material used in seal-- Did any strata contain unusable water? [ ] Yes [ ] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 110 ft. below land surface Date Artesian pressure lbs. per square inch Date Log Accepted by: [Signed] Date, 19 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [ ] No If yes, by whom? Yield: 190 gal./min. with 3 ft. drawdown after hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [ ] Yes [ ] No

(12) WELL LOG:

Diameter of well 10 inches. Depth drilled 235 ft. Depth of completed well ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include sand, loose, and silt (0-65), sand and cemented gravel (65-140), gravel, loose, water bearing (140-144), sand and cemented gravel (144-174), sand and gravel, loose (174-180), sand, green, loose (180-189), sand, green, loose rock (189-212).

Work started 19 Completed Sept 1938

(13) PUMP:

Manufacturer's Name Bingham Type: Turbine H.P. 10

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME (Person, firm, or corporation) (Type or print)

Address

Driller's well number

[Signed] (Well Driller)

License No. Date, 19

