

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

**RECEIVED**  
 SEP 19 1968  
 STATE ENGINEER  
 SALEM OREGON

**WATER WELL REPORT**

STATE OF OREGON

(Please type or print)

(Do not write above this line)

**MULT**

2750

Well No. 1/1-4 H

State Permit No.

**(1) OWNER:**

Name PORTLAND STATE COLLEGE  
 Address 224 SW HARRISON ST.  
PORTLAND, OREGON

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
 16" Diam. from 0 ft. to 232 ft. Gage 315  
 " Diam. from ft. to ft. Gage  
 " Diam. from ft. to ft. Gage

**(6) PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used STAR  
 Size of perforations 3/8 in. by 1/4 in.  
960 perforations from 188 ft. to 205 ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name  
 Type Model No.  
 Diam. Slot size Set from ft. to ft.  
 Diam. Slot size Set from ft. to ft.

**(8) WATER LEVEL: Completed well.**

Static level 135'4" ft. below land surface Date 8/26/68  
 Artesian pressure lbs. per square inch Date

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? STRASSER  
525 gal./min. with 55 ft. drawdown after 8 hrs.  
390 " 31 " 10 "  
 " 180 " 10 " 12 "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 55° Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used CEMENT  
 Depth of seal 20 FT BELOW BASEMENT ft.  
 Diameter of well bore to bottom of seal 20 in. FLOOR  
 Were any loose strata cemented off?  Yes  No Depth  
 Was a drive shoe used?  Yes  No  
 Did any strata contain unusable water?  Yes  No  
 Type of water? depth of strata  
 Method of sealing strata off  
 Was well gravel packed?  Yes  No Size of gravel:  
 Gravel placed from ft. to ft.

**(11) LOCATION OF WELL:**

County MULT. Driller's well number 4282  
SE 1/4 NE 1/4 Section 4 T. 15 R. 1E W.M.  
 Bearing and distance from section or subdivision corner

**(12) WELL LOG:**

Diameter of well below casing

Depth drilled 232 ft. Depth of completed well 232 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
BASEMENT	0	10	
BROWN SAND	10	87	
SAND, SILT AND GRAVEL	87	113	
SOFT CEMENTED GRAVEL	113	130	
LOOSE SAND AND GRAVEL	130	155	
CEMENTED SAND AND GRAVEL	155	186	
LOOSE SAND AND GRAVEL	186	216	
CEMENTED GRAVEL	216	224	
HARD CEMENTED GRAVEL	224	227	
GRAVEL AND CLAY	227	232	
BLACK DECOMPOSED ROCK	232	232-6	

Work started JULY 18 1968 Completed SEPT 3 1968

Date well drilling machine moved off of well SEPT 5 1968

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] William Rudman Date SEPT 17 1968  
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 54

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STRASSER DRILLING CO  
 (Person, firm or corporation) (Type or print)

Address 8110 SE SUNSET LANE PORTLAND ORE

[Signed] Robert L Strasser  
 (Water Well Contractor)

Contractor's License No. 10 Date SEPT 17 1968