

MULT
2751

RECEIVED

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

SEP 1 1964 WATER WELL REPORT

Well No. 111-4B

STATE OF OREGON (Please type or print)

G3101

State Permit No.

(1) OWNER:

Name KING BROADCASTING Co
Address 320 AURORA AVE.
SEATTLE, WASH

(2) LOCATION OF WELL:

County MULT Driller's well number 4175
NW 1/4 NE 1/4 Section 4 T. 15 R. 1E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 230 ft. Gage 279
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used STAR
Size of perforations 3/8 in. by 1 1/4 in.
640 perforations from 142 ft. to 158 ft.
400 perforations from 218 ft. to 228 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT GROUT
Depth of seal 44 ft. Was a packer used? No
Diameter of well bore to bottom of seal 14 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 710 ft. below land surface Date AUG 20 1964
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level.
Was a pump test made? Yes No If yes, by whom? R. STRASSER DRILLING CO
Yield: 258 gal./min. with 110 ft. drawdown after 10 hrs.
" 200 " 60 " 1 "
" 150 " 39 " 1 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 53° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 10
Depth drilled 285 ft. Depth of completed well 285 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
FILL	0	19
BLUE SILT	19	24
SILT AND SAND SOME GRAVEL	24	76
HARD PACKED SAND	76	87
CEMENTED GRAVEL	87	148
SAND AND GRAVEL (WATER)	148	183
DIRTY SAND AND GRAVEL	183	211
SAND AND GRAVEL (WATER)	211	229
HARD GREY ROCK	229	234
MED. HARD BLACK ROCK	234	242
ROUGH BROKE ROCK	242	251
DECOMPOSED ROCK	251	259
MED. HARD BLACK ROCK	259	283

Work started July 22 1964 Completed AUG 25 1964
Date well drilling machine moved off of well AUG 26 1964

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STRASSER DRILLING CO (Person, firm or corporation) (Type or print)
Address 8110 SE SUNSET LANE PORTLAND ORE.
Drilling Machine Operator's License No. 58
[Signed] Robert L. Strasser (Water Well Contractor)
Contractor's License No. 10 Date SEPT 9 1964