

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED

OCT 5 1962

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

RECEIVED

OCT 22 1962

STATE ENGINEER

SALEM, OREGON

MULT 2752 1174

State Well No.

State Permit No.

(1) OWNER:

Name NORTHWEST HOSPITAL SERVICE
Address 1320 S.W. BROADWAY
PORTLAND 4, ORE.

(2) LOCATION OF WELL:

County MULT Driller's well number 4132
1/4 Section 4 T. 15 R. 1E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [X] Municipal []
Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

12" Diam. from 0 ft. to 206 ft. Gage 330
Threaded [] Welded [X]

(7) PERFORATIONS:

Perforated? [X] Yes [] No
Type of perforator used STAR
Size of perforations 1/4 in. by 1/4 in.
540 perforations from 160 ft. to 169 ft.
470 perforations from 178 ft. to 185 ft.

(8) SCREENS:

Well screen installed [] Yes [X] No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT GROUT
Depth of seal 50 ft. Was a packer used? [X]
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 138 ft. below land surface Date 9/21/62
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom? R.J. STRASSER
Yield: 340 gal./min. with 25 ft. drawdown after 24 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 55 Was a chemical analysis made? [X] Yes [] No

(12) WELL LOG:

Diameter of well below casing 12
Depth drilled 207 ft. Depth of completed well 207 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include SANDY (DRY), SAND AND SILT, CEMENTED GRAVEL, LOOSE SAND AND GRAVEL, BLUE CLAY, SAND AND GRAVEL, BLUE BLACK CLAY, BROKEN ROCK, BLACK ROCK.

Work started AUG 31 19 62 Completed SEPT 25 19 62
Date well drilling machine moved off of well SEPT 26 19 62

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R.J. STRASSER DRILLING CO.
Address 8110 S.E. SWANSET LANE PORTLAND ORE

Drilling Machine Operator's License No. 56

[Signed] Robert J. Strasser
(Water Well Contractor)

Contractor's License No. 10 Date Oct 3, 19 62