NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

MULT 06 12784

WATER WELL REPORT
STATE OF OREGON
(please type or print)
(write above this line)

RECEIVED MAR 26 1975 STATE ENGINEER SALEM, OREGON

State Well No. 1S/1E-13
State Permit No.

(1) OWNER:
Name Jerry Forchuk
Address 5216 SE 32
Portland, OR.

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:
Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 77 ft. Gage .250"
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 35 gal./min. with 1 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 21 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 21 sacks
Brand name of bentonite National
Number of pounds of bentonite per 100 gallons of water 75 lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Multnomah Driller's well number 75-2
¼ ¼ Section 13 T. 1S R. 1E W.M.
Bearing and distance from section or subdivision corner
TL 133

(11) WATER LEVEL: Completed well.
Depth at which water was first found 74 ft.
Static level 60 ft. below land surface. Date 3/12/75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 80 ft. Depth of completed well 77 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top soil	0	1	
Brown clay with fine sand	1	50	
Fine sand	50	58	
Brown clay & gravel	58	74	
Gravel & sand (water)	74	79	60
Brown clay & gravel	79	80	

Work started Mar. 10 1975 Completed Mar. 12 1975
Date well drilling machine moved off of well Mar. 12 1975

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Daniel V. Wyland (Drilling Machine Operator) Date 3/12, 1975
Drilling Machine Operator's License No. 718

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name D.V. Wyland Co. (Person, firm or corporation) (Type or print)
Address Rt. 1 Box 324 Molalla, OR. 97038
[Signed] Daniel V. Wyland (Water Well Contractor)
Contractor's License No. 554 Date Mar. 12, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)