RECEIVED
MAY 21 1963
STATE ENGINEER
SALEM, OREGON

MULT
62836

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 1/1-35

G2868 State Permit No.

(1) OWNER:
Name Phil Fields
Address 107 S E Grand Ave. Portland, Oregon

(2) LOCATION OF WELL:
County Multnomah Driller's well number
¼ ¼ Section 35 T. 1S R. 1E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☒ Other ☒

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☒
8" Diam. from 0 ft. to 58'1 ft. Gage .277
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cement
Depth of seal 58 ft. Was a packer used? No
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 39 ft. below land surface Date 4/63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Jannsen Drillin
Yield: 73 gal./min. with 65 ft. drawdown after 4 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 54° Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:
Diameter of well below casing 8"
Depth drilled 161 ft. Depth of completed well 161 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifiers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Silty Sand	0	11
Boulders and Gravel	11	20
Sand, Gravel, Clay & Boulders	20	43
Cemented Gravel	43	57
Basalt Rock	57	75
Broken Basalt	75	86
Basalt Rock	86	93
Black coal-like Rock-Brown sand with fine yellow-4' rise in static	93	96
Basalt Rock	96	109
Grey Porous Rock	109	117
Grey hard Basalt with crevice	117	140
Porous Basalt	140	146
Hard Grey Basalt	146	158
Hard Grey Broken Basalt	158	161

Work started 3/12/ 1963. Completed 5/10 1963
Date well drilling machine moved off of well 5/10/63 19

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A. M. Jannsen Drilling Co.
(Person, firm or corporation) (Type or print)
Address Aloha, Oregon
Drilling Machine Operator's License No. 234
[Signed] Edward M. Jannsen
(Water Well Contractor)
Contractor's License No. 79 Date 5/23, 1963

(USE ADDITIONAL SHEETS IF NECESSARY)