

The original and first copy of this report are to be filed with the

WATER WELL REPORT MULT

STATE OF OREGON (Please type or print)

State Well No. 13/2E2db

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion

(Do not write above this line)

2841

(1) OWNER:

Name DAVID DOUGLASS SCHOOL DIST. Address 2900 SE 82ND AVE PORTLAND, ORE.

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(10) LOCATION OF WELL:

County MULT. Driller's well number 5528 NW 1/4 SE 1/4 Section 2 T. 15 R. 2E W.M. Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 275 ft. Static level 124 ft. below land surface. Date 5/12/77 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing - Depth drilled 350 ft. Depth of completed well 325 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: TOP SOIL, SAND GRAVEL Boulders, BROWN SAND AND GRAVEL, LOOSE SAND AND GRAVEL, GRAVEL Boulders CLAY, DRY SAND AND GRAVEL, RED CLAY AND GRAVEL, CEMENTED GRAVEL, SAND AND GRAVEL, BROWN CLAY AND GRAVEL, GREY CLAY AND GRAVEL, SAND AND GRAVEL, CEMENTED GRAVEL.

CASING INSTALLED:

Threaded [] Welded [X] 8" Diam. from +1 ft. to 326 ft. Gage 277

PERFORATIONS:

Perforated? [X] Yes [] No. Type of perforator used STAR Size of perforations 3/8 in. by 1 1/4 in. 300 perforations from 275 ft. to 285 ft. 450 perforations from 307 ft. to 322 ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? STRASSER Yield: 296 gal./min. with 124 ft. drawdown after 12 hrs. 250 " 100 " " 200 " 74 " " Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT GROUT Well sealed from land surface to 33 ft. Diameter of well bore to bottom of seal 12 in. Diameter of well bore below seal 8 in. Number of sacks of cement used in well seal 32 sacks Number of sacks of bentonite used in well seal Brand name of bentonite Number of pounds of bentonite per 100 gallons of water lbs./100 gals. Was a drive shoe used? [X] Yes [] No Plugs Size: location ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

Work started MAR 21 19 77 Completed MAY 11 19 77 Date well drilling machine moved off of well MAY 11 19 77

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Jerry Johnson Date MAY 12, 1977 Drilling Machine Operator's License No. 911

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name R. STRASSER DRILLING Co Address 8110 SE SUNSET LANE PORTLAND ORE. [Signed] Robert J. Strasser Contractor's License No. 70 Date MAY 12, 1977