

RECEIVED
OCT 31 1960

STATE ENGINEER WATER WELL REPORT
SALEM, OREGON STATE OF OREGON

MULT
2864

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

State Well No. 1/2-10A
State Permit No.

(1) OWNER:

Name Fred Meyer
Address 721 S.W. 4th St. Portland, Oregon
(122nd and Division Store)

(2) LOCATION OF WELL:

County Multnomah Owner's number, if any--
NE 1/4 NE 1/4 Section 10 T. 18 S. R. 2E W.M.
Bearing and distance from section or subdivision corner
470 ft. South and 460 ft. West from the NE corner of Section 10

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

12" Diam. from 0 ft. to 256 ft. Gage std.
10" Diam. from 240 ft. to 335 ft. Gage "
" Diam. from " ft. to " ft. Gage "

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Star
SIZE of perforations 3/8 in. by 1 1/4 in.
40 / ft. perforations from 305 ft. to 314 ft.
40 / ft. perforations from 316 ft. to 325 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Type Model No.
Slot size Set from " ft. to " ft.
Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from " ft. to " ft.
Was a surface seal provided? Yes No To what depth? " ft.
Material used in seal--
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 112 ft. below land surface Date Sept. 3
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Fred Meyer (Owner) Date 10/27, 1960

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Strasser
Was a pump test made? Yes No If yes, by whom? Drilling Co.
Yield: 250 gal./min. with 61 ft. drawdown after 4 hrs.
" 300 " " 73 " " 4 "
" 350 " " 86 " " 8 "
Ballor test gal./min. with " ft. drawdown after " hrs.
Artesian flow g.p.m. Date
Temperature of water 51 F Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 12 inches.
Depth drilled 335 ft. Depth of completed well 335 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Topsoil	0	4
Gravel, clay and boulders	4	9
Sand and gravel, some binder	9	73
Cemented gravel	73	106
Loose gravel and sand	106	117
Gravel, some sandy clay binder	117	144
Sandy clay	144	151
Small gravel and sandy clay	151	161
Gravel and sandy clay	161	212
Cemented gravel	212	225
Gravel and sandy clay	225	251
Cemented gravel	251	269
Gravel, sand and clay	269	282
Some loose gravel and sand	282	304
Loose gravel and sand (water)	304	329
Cemented gravel	329	335

Work started July 17 1959 Completed Sept. 5 1959

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. J. Strasser Drilling Co.
(Person, firm, or corporation) (Type or print)
Address 8110 SE Sunset Lane, Portland 6, Ore.

Driller's well number 4012
[Signed] Robert J. Strasser (Well Driller)
License No. 10 Date Sept. 9, 1959