

G 674

WATER WELL REPORT **MULT**
STATE OF OREGON

State Well No. 1/2-19P(1)
Permit No. G-610

(1) OWNER:

Name PRECISION CASTPARTS CORP.
Address 4600 S.E. HARNEY DRIVE
PORTLAND 6, OREGON

(2) LOCATION OF WELL:

County Multnomah Owner's number, if any—
SE 1/4 SW 1/4 Section 19 T. 1S R. 2E W.M.
Bearing and distance from section or subdivision corner
Approx. 337 ft. S. and approx. 787 ft. E.
from the SE corner of Jacob Wills D.L.C.

TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from top ft. to full depth Standard weight.
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 20 to 21
Material used in seal— Sand gravel 7 cement
Did any strata contain unusable water? Yes No
Type of water? to sandy Depth of strata 80 to 85 ft.
Method of sealing strata off drove casing past it.

(10) WATER LEVELS:

Static level 8 ft. below land surface Date 6/21/57
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] S.W. Cook Date Sept. 30, 1957
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 120 gal./min. with 15 ft. drawdown after 6 hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 54° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 8 inches.
Depth drilled 105 ft. Depth of completed well 105 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Sand	1	12
Clay	12	20
Gravel & Clay	20	30
Cemented gravel	30	50
Sand & Gravel	50	80
" " " w/ a little water	80	85
Gravel & Yellow Sand	85	95
Gravel with good supply of water	95	105

RECEIVED
JUL 1 1957

Work started June 7 1957. Completed June 21 1957

(13) PUMP:

Installed July 1 1957
Manufacturer's Name BYRON JACKSON (BEE JAY)
Type: DEEP WELL TURBINE H.P. 7 1/2

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME HAAKON I. BOTTNER WELL DRILLING
(Person, firm, or corporation) (Type or print)
Address 11544 N. E. GLISAN ST.
PORTLAND 16, OREGON

Driller's well number
[Signed] Hakon Bottner
(Well Driller)
License No. 190 Date 9/12/, 1957
109