

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

RECEIVED FEB 19 1934

WATER WELL REPORT STATE OF OREGON

MULT 2897

State Well No. 4/2-19 P State Permit No. G-2514

(1) OWNER: ( Well No. 2 )

Name Precision Cast Parts Corp.  
Address 4600 S.E. Harney Drive  
Portland 6, Oregon

(2) LOCATION OF WELL:

County Multnomah Owner's number, if any—  
1/4 Section 19 T. 1so, R. 2E. W.M.  
Bearing and distance from section or subdivision corner  
Part of Lot 1 of Gibson Subdivision  
the J.A. Logan Track

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 204 ft. Gage 275  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used Mills Knife  
SIZE of perforations 3/8 in. by 2 in.  
50 perforations from 55 ft. to 60 ft.  
120 perforations from 90 ft. to 102 ft.  
70 perforations from 153 ft. to 160 ft.  
150 perforations from 175 ft. to 190 ft.

SCREENS:

Well screen installed  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) CONSTRUCTION:

Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Was a surface seal provided?  Yes  No To what depth? 23 ft.  
Material used in seal— Cement & Sand  
Did any strata contain unusable water?  Yes  No  
Type of water? Depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 13 ft. below land surface Date  
Artesian pressure lbs. per square inch Date

Log Accepted by:  
[Signed] \_\_\_\_\_ Date \_\_\_\_\_, 19\_\_\_\_  
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? Bottner Drilling Co.  
Yield: 150 gal./min. with 20 ft. drawdown after 4 hrs.  
" 200 " 35 " 4  
" 225 " 40 " 6

Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 51° Was a chemical analysis made?  Yes  No

(12) WELL LOG: Diameter of well 10 inches.

Depth drilled 231 ft. Depth of completed well back filled to 205 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Soil, brown, dark	0	5
Gravel, coarse, & boulders	5	12
Clay, blue	12	28
Clay, yellow	28	33
Sand, coarse, black & yellow	33	34
Gravel, fine	34	66
Sand, coarse	66	69
Gravel, fine	69	89
Gravel, medium, black	89	108
Sand, coarse, brown	108	114
Clay, yellow, sandy	114	118
Gravel, medium	118	138
Clay, yellow, & gravel medium	138	151
Gravel, medium	151	153
Gravel, medium, cemented	153	162
Gravel, medium, brown	162	175
Gravel, medium, gray, water	175	185
Gravel, fine, black, water B	185	193
Clay, yellow	193	215
Clay, reddish, coarse	215	222
Sand, white	222	224
Clay, brown	224	231

Delayed for: Waited for Test Pump  
Work started Aug. 14 19 63 Completed Oct. 23 1963

(13) PUMP:

Manufacturer's Name Western Land Roller  
Type: Turbine, water lube H.P. 20-1800 RPM  
Motor U.S.

Well Driller's Statement:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME HAAKON BOTTNER DRILLING COMPANY  
(Person, firm, or corporation) (Type or print)  
Address 11544 N. E. GLISAN ST.  
PORTLAND 20, OREGON  
Driller's well number

[Signed] H. Bottner (Well Driller)  
License No. 109 Date Nov. 23, 1963