

RECEIVED

MULT

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

NOV 12 1965 WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON

STATE ENGINEER STATE OF OREGON (Please type or print) SALEM OREGON

2927

Well No. 1/3-2 M

State Permit No.

(1) OWNER:

Name Gresham Golf & Country Club
Address 2155 N.E. DIVISION
GRESHAM, OREGON 97030

(2) LOCATION OF WELL:

County Multnomah Driller's well number
N.W 1/4 S.W. 1/4 Section 2 T. 1S R. 3E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []
Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 289 ft. Gage .279
8" Diam. from 282 ft. to 300 ft. Gage .277

(7) PERFORATIONS:

The 10" Star 4 way drive down liner with 3/8" perforations
10" 120 perforations from 164 ft. to 169 ft.
" 96 perforations from 189 ft. to 193 ft.
" 96 perforations from 243 ft. to 247 ft.
" 120 perforations from 250 ft. to 255 ft.
" 96 perforations from 267 ft. to 271 ft.
8" 36 " " 288 ft " 294 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement & Sand
Depth of seal 27 ft. Was a packer used? No
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? [] Yes [X] No
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 118 ft. below land surface Date 7/30/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Bottner

Was a pump test made? [X] Yes [] No If yes, by whom? Drilling Co
Yield: 250 gal./min. with 34 ft. drawdown after 7 hrs.
" 418 " 54 " 9 "
" " " " "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 53° Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 10"

Depth drilled 300 ft. Depth of completed well 300 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Soil, top, Clay, yellow, Gravel, cemented, Clay, blue, Gravel, cemented, Gravel, water bearing, Gravel, cemented, Gravel, water bearing, Sand, Gray, Gravel, cemented, Gravel, W/brng. approx 75 to 100 g.p.m. w/ 20 ft. D., Gravel, cemented, Gravel, w/ water, Gravel, cemented, Gravel, water bearing, Gravel, cemented, Sand, black coarse, & Gravel, water bearing, Clay, gray.

Work started 5/7/ 1965 Completed 6/28/ 1965
Date well drilling machine moved off of well July 7 1965

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME HAAKON BOTTNER DRILLING COMPANY
(Person, firm or corporation) (Type or print)

Address 3424 S.E. 174th. AVE. PORTLAND OREGON

Drilling Machine Operator's License No. 246

[Signed] Haakon Bottner
(Water Well Contractor)

Contractor's License No. 109 Date , 19