

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

JAN 21 1963

WATER WELL REPORT

STATE OF OREGON

MULT

22404
6574

Well No. 1/3-3C(1)

State Permit No.

(1) OWNER:

Name J. Frank Schmidt & Son Company
Address 23000 S.E. Stark Street
Troutdale, Oregon

(2) LOCATION OF WELL:

County Multnomah Owner's number, if any—
1/4 1/4 Section 3 T. 1S R. 3E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

12" Diam. from 0 ft. to 437 ft. Gage 5/16
10" Diam. from 427 ft. to 622 ft. Gage "
" Diam. from " ft. to " ft. Gage "

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used 1 way Star Drive Down & Tech
SIZE of perforations 1 1/4 in. by 3/8 in.
72 perforations from 115 ft. to 118 ft.
96 perforations from 226 ft. to 230 ft.
120 perforations from 350 ft. to 355 ft.
120 perforations from 360 ft. to 365 ft.
10 perforations from 450 ft. to 620 ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 40 ft.
Material used in seal— Cement & Sand
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 125 ft. below land surface Date 6/29/62
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by: _____

[Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Bottner Drilling Co

Was a pump test made? Yes No If yes, by whom? _____
Yield: 300 gal./min. with 125 ft. drawdown after 36 hrs.

Bailer test gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow g.p.m. Date _____

Temperature of water 53 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 10 inches.

Depth drilled 635 ft. Depth of completed well 635 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Yellow Clay	0	6
Yellow Dirty Gravel	6	36
Boulders	36	38
Fine Dry Gravel	38	40
Yellow Clay	40	46
Cemented Gravel	46	82
Gravel (Water Bearing)		
Yellow Clay	82	97
Cemented Gravel	97	115
Gravel (Water Bearing)	115	118
Sandy Yellow Clay	118	148
Grey Clay	148	216
Cemented Gravel	216	309
Grey Sand	309	310
Cemented Gravel	310	440
Black Solid Rock	440	470
Grey Clay	470	482
Grey Rock	482	506
Grey Rock w/soft spots	506	592
Yellow Clay	592	602
Black Rock	602	618
Sandy Yellow Clay	618	635

(Customer wants to drill

deeper) UNCOMPLETED

Work started 6/29 19 62 Completed _____ 19 _____

(13) PUMP:

(None as yet)

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME HAAKON BOTTNER DRILLING COMPANY
(Person, firm, or corporation) (Type or print)

Address 3424 S.E. 174th

Driller's well number _____

[Signed] W. E. Smith
(Well Driller)

License No. 375 Date _____, 19____