

DEC 23 1963

WATER WELL REE STATE OF OREGON

MULT 2959

1/3-6

Well No. State Permit No. G 2240

(1) OWNER:

Name The Mobile Estate Corp.
Address 16745 S.E. Division St.
Portland Oregon

(2) LOCATION OF WELL: Tax Lots 225-351

County Multnomah Owner's number, if any—
1/4 1/4 Section 6 T. 3E R. 1 So. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Tri. Court Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED: Threaded Welded
12" Diam. from 0 ft. to 205 ft. Gage 2.79
Liners 8" Diam. from 170 ft. to 273 ft. Gage .250

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used 12" 4 way Dr. D. 8" torch
SIZE of perforations 12"-3/8x12" by 8" 3/16 in. 6"
12" 240 perforations from 153 ft. to 163 ft.
" 120 perforations from 175 ft. to 180 ft.
" 120 perforations from 190 ft. to 195 ft.
8" 196 perforations from 170 ft. to 273 ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 27 ft.
Material used in seal— sand, gravel and cement
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 60 ft. below land surface Date
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Bottner
Was a pump test made? Yes No If yes, by whom? Drilling Co
Yield: 100 gal./min. with 22 ft. drawdown after 4 hrs.
" 200 " " 36 " " 8 "
" 250 " " 44 " " 8 "
~~300~~ gal./min. with 51 ft. drawdown after 10 hrs.
Artesian flow g.p.m. Date
Temperature of water 54° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 12" & 10" inches.
Depth drilled 273 ft. Depth of completed well 273 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Clay, brown & gravel	0	4
Boulders & Gravel	4	16
Gravel cemented	16	36
Gravel & fine gray sand	57	68
Gravel cemented	68	117
Gravel & 1/4 gray sand	117	163
Cemented gravel w/water seams	163	180
Gravel & Sand	180	190
Gravel, cemented	190	198
Gravel & sand	198	205
Gravel, cemented	205	213
Clay, blue	213	216
Gravel, cemented	216	230
Gravel & sand (water bearing)	230	273

Note :Drl. Rig & Pmp. Eqmpt., moved off & on
Due to other construction, completion
delayed. Pulled Turbine test pump. On
approval, installed a used 2 1/2 H.P.
submersible., Water now crystal clear
and free from sand, approved and accepted
by customer.

Work started 3/22 1963 Completed Oct. 21 1963

(13) PUMP: just temporarily as above

Manufacturer's Name
Type: Sub. (Used) H.P. 2 1/2 H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME HAAKON BOTTNER DRILLING COMPANY
(Person, firm, or corporation) (Type or print)

Address 11544 N. E. GLISAN ST.
PORTLAND 20, OREGON

Driller's well number

[Signed] H. Bottner
(Well Driller)

License No. 109 Date 12-6- 1963