NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED OCT 13 1971 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

(Please type or print)
(Do not write above this line)

MULT 916

State Well No. 1N/1-2ad

State Permit No.

(1) OWNER:
Name COLUMBIA EDGEWATER GOLF CLUB
Address 2137 NE MARINE DRIVE PORTLAND, ORE 97211

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from +2 ft. to 132 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used STAR
Size of perforations 3/8 in. by 1 1/4 in.
105 perforations from 122 ft. to 129 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? STRASSER
Yield: 230 gal./min. with 5 ft. drawdown after 4 hrs.
" " "
" " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used CEMENT GROUT
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 12 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County MULT. Driller's well number 52-89
SE ¼ NE ¼ Section 2 T. 1N R. 1E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 108 ft.
Static level 4 ft. below land surface. Date OCT 2, 1971
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing —
Depth drilled 132 ft. Depth of completed well 132 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
SILT AND SAND	0	9	
BLUE CLAY	9	49	
SAND AND SILT	49	108	
WATER BEARING GRAVEL	108	132	

Work started SEPT 23 1971 Completed OCT 4 1971
Date well drilling machine moved off of well OCT 4 1971

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] [illegible] (Drilling Machine Operator) Date OCT 11, 1971
Drilling Machine Operator's License No. 57

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name R.J. STRASSER DRILLING CO (Person, firm or corporation) (Type or print)
Address 8110 SE SUNSET LANE PORTLAND, ORE.
[Signed] Robert L. Strasser (Water Well Contractor)
Contractor's License No. 10 Date OCT 11, 1971

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119