

NOTICE TO WATER WELL CONTRACTORS

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT APR 17 1970 STATE OF OREGON (Please type or print) STATE ENGINEER SALEM, OREGON

MULT 918

State Well No. IN/1-2 ad State Permit No.

(1) OWNER:

Name COLUMBIA EDGEWATER COUNTRY CLUB Address 2137 NE MARINE DRIVE PORTLAND, ORE.

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [X] Irrigation [] Test Well [] Other []

CASING INSTALLED:

20" Diam. from 0 ft. to 140 ft. Gage 375 14" Diam. from 124.6 ft. to 146.6 ft. Gage 375 14" Diam. from 164 ft. to 172 ft. Gage 375

(6) PERFORATIONS:

Perforated? [] Yes [X] No.

Size of perforations in. by in. perforations from ft. to ft. perforations from ft. to ft. perforations from ft. to ft. perforations from ft. to ft. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [X] Yes [] No

Manufacturer's Name U.D.P. JOHNSON Type STAINLESS STEEL Model No. Diam. 1.6 Slot size 120 Set from 146.6 ft. to 164 ft. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 22 ft. below land surface Date APR 13 1970 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? STRASSER Yield: 1200 gal./min. with 3 ft. drawdown after 1 hrs. 1700 " 5 " 2 " 2150 " 7 " 9 " Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 53° Was a chemical analysis made? [X] Yes [] No

(10) CONSTRUCTION:

Well seal—Material used READY MIX CONCRETE Depth of seal 10-30 FT ft. Diameter of well bore to bottom of seal 24 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County MULT Driller's well number 5238 SE 1/4 NE 1/4 Section 2 T. 10 R. 1E W.M. Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing

Depth drilled 172 ft. Depth of completed well 172 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows: GRAVEL AND BouldERS (0-18), PACKED SAND (18-140), WATER BEARING GRAVEL (140-172)

Work started MAR 18 1970 Completed APR 15 1970 Date well drilling machine moved off of well APR 15 1970

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Don Johnson Date APR 15 1970 (Drilling Machine Operator)

Drilling Machine Operator's License No. 56

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STRASSER DRILLING Co (Person, firm or corporation) (Type or print)

Address 8110 SE SUNSET LAKE PORTLAND ORE

[Signed] Robert L. Strasser (Water Well Contractor)

Contractor's License No. 10 Date APR 15, 1970