

NOTICE TO WATER WELL CONTRACTOR:

The original and first copy of this report are to be filed with the

RECEIVED
 DEC 30 1964
 STATE ENGINEER

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date of well completion.

(Please type or print)

MULT
 930
 2967

State Well No. 10/1-4J

State Permit No.

(1) OWNER:

SALEM, OREGON

Name OREGON STATE HIGHWAY DEPT.
 Address 5921 NE GLISAN PORTLAND ORE
 MINNESOTA FREEWAY NORTH UNIT

(2) LOCATION OF WELL:

County MULT Driller's well number 4181
 NE 1/4 SE 1/4 Section 4 T. 10 R. 1E W.M.
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 abandonment, describe material and procedure in Item 12.

PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded

8" Diam. from 0 ft. to 180 ft. Gage 277
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used STAR

Size of perforations 3/8 in. by 1 1/4 in.
 450 perforations from 160 ft. to 175 ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
 Type Model No.
 Slot size Set from ft. to ft.
 Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT GROUT
 Depth of seal 42 ft. Was a packer used? NO
 Diameter of well bore to bottom of seal 12 in.
 Were any loose strata cemented off? Yes No Depth
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.
 Did any strata contain unusuable water? Yes No
 Type of water? depth of strata
 Method of sealing strata off

(10) WATER LEVELS:

Static level 21 ft. below land surface Date 11/30/64
 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? R.J. STRASSER DRILLING CO
 Yield: 100 gal./min. with 1 ft. drawdown after 6 hrs.
 " " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 54 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing

Depth drilled 179 ft. Depth of completed well 179 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
CLAY	0	4
GREY SANDY SILT	4	98
CLAY AND GRAVEL	98	102
SAND	102	138
CEMENTED GRAVEL	138	145
GRAVEL SAND, AND SILT	145	153
LOOSE SAND AND GRAVEL	153	179

Work started NOV 2 1964 Completed DEC 4 1964
 Date well drilling machine moved off of well DEC 4 1964

(13) PUMP:

Manufacturer's Name
 Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R.J. STRASSER DRILLING CO
 (Person, firm or corporation) (Type or print)

Address 8110 S.E. SUNSET LAKE PORTLAND ORE

Drilling Machine Operator's License No. 190

[Signed] Robert J. Strasser
 (Water Well Contractor)

Contractor's License No. 10 Date DEC 14 1964