NOTICE TO WATER WELL CONTRACTOR OF MULT The original and first copy of this report are to be filed with the STATE OF OREGON STATE OF OREGON MULT MULT Add b State Well No. /N/1-5				
STATE OF OREGON STATE ENGINEER, SALEM, OREGON 97310 Within 30 days from the date of well completion. (Do not write above this line) State Well No. State Permit No.				
(1) OWNER: Name PERTLAND RENDERING CO	(11) LOCATION OF WELL: County MCLT, Driller's well not	mber 4	425	3
Address FOOT OF N. HURST AUE.	SE 4 SE 4 Section 5 T. IN R. RIE W.M.			
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner			
New Well Deepening Reconditioning Abandon I If abandonment, describe material and procedure in Item 12.				
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing			
Rotary Driven Domestic Industrial Municipal	Depth drilled /CC ft. Depth of completed well /CC ft.			
CASING INSTALLED: Threaded Welded William from C ft. to 100-6 ft. Gage 330	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.			
"Diam. from ft. to ft. Gage ft	MATERIAL	From	To To	swL .
	FILL	0	6.	
PERFORATIONS: Perforated? Yes No.	SILT AND SAND	46	46 58	
Type of perforator used 57AR	BROWN SAND SAND AND GRAVEL	58	72	
dize of perforations 3/8 in. by //4 in.	BROWN SAND	72	80	
540 perforations from 82 ft. to 92 ft.	WATER BEAKING GRADE	80	/වල	
perforations fromft. toftftftftftftft.				
perforations fromft. toft.				
perforations from ft. to ft.				
(7) SCREENS: Well screen installed? Yes No		:		
Manufacturer's Name				
TypeModel No Diam, Slot size Set from ft. to ft.				
Diam. Slot size Set from ft. to ft.				
(8) WATER LEVEL: Completed well.				
Static level /7 ft. below land surface Date 9/13/67				
Sian pressure lbs. per square inch Date				
9) WELL TESTS: Drawdown is amount water level is lowered below static level				
Was a pump test made? Yes I No If yes, by whom? STRA SSER	Work started SEPT 19 67 Complet	ed 52	10m /	4 196-7
vield: 1200 gal./min. with 1/7ft. drawdown after 1/2 hrs.	Date well drilling machine moved off of well SEPT 15-1967			
7000 " 7 " 3 "	Drilling Machine Operator's Certification:			
Bailer test gal./min. with ft. drawdown after hrs.	This well was constructed under my drials used and information reported above	irect sup ve are t	ervision rue to	n. Mate- my best
Artesian flow g.p.m. Date	knowledge and belief)		V= 17	1 67
Temperature of water 52 Was a chemical analysis made? 🗆 Yes 🕽 No	[Signed] Date Date 19, 19			
(10) CONSTRUCTION:	Drilling Machine Operator's License No.	ک	7	
Well seal—Material used CEMENT AND BENTOWITE	Water Well Contractor's Certification:			
Depth of sealft. Diameter of well bore to bottom of sealin.	This well was drilled under my jurisdiction and this report is			
Were any loose strata cemented off? Yes No Depth	true to the best of my knowledge and belief.			
Was a drive shoe used? Yes 🗆 No	NAME (Person, firm or corporation) (Type or print)			
Did any strata contain unusable water? Yes X No	Address SIIO SE SUNSET LANE PORTLAND ON			
Type of water? depth of strata	Robert & Share			
Method of sealing strata off Was well gravel packed? ☐ Yes X No Size of gravel:	[Signed] (Water Well Contractor)			
Gravel placed fromft. toft.	Contractor's License No. 10 Date 007 7, 1967			