

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

**RECEIVED**  
**SEP - 5 1962**  
**STATE ENGINEER**

**WATER WELL REPORT**

STATE OF OREGON  
 (Please type or print)

**MULT**  
**939**

State Well No. 11/1-7F  
 State Permit No. \_\_\_\_\_

**(1) OWNER:**

Name FRED MEYER INC  
 Address 721 SW 4TH AVE.  
PORTLAND ORE

**(2) LOCATION OF WELL:**

County MULT. Driller's well number 4130  
SE 1/4 NW 1/4 Section 7 T. 1N R. 1E W.M.  
 Bearing and distance from section or subdivision corner  
2250 FT SOUTH AND 1625 FT.  
EAST FROM THE N.W. CORNER

LOCATED IN LOT 25 BLOCK 1  
OF HEPPNER SUBDIVISION

**(3) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
 Abandonment, describe material and procedure in Item 12.

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

**(5) TYPE OF WELL:**

Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

**(6) CASING INSTALLED:**

Threaded  Welded   
12" Diam. from 0 ft. to 248 ft. Gage 312  
 " Diam. from " ft. to " ft. Gage  
 " Diam. from " ft. to " ft. Gage

**(7) PERFORATIONS:**

Perforated?  Yes  No  
 Type of perforator used STAR  
 Size of perforations 1/4 in. by 1/4 in.  
400 perforations from 184 ft. to 194 ft.  
480 perforations from 228 ft. to 240 ft.  
 perforations from " ft. to " ft.  
 perforations from " ft. to " ft.  
 perforations from " ft. to " ft.

**(8) SCREENS:**

Well screen installed  Yes  No  
 Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
 " Slot size " Set from " ft. to " ft.  
 " Slot size " Set from " ft. to " ft.

**(9) CONSTRUCTION:**

Well seal—Material used in seal CEMENT GROUT  
 Depth of seal 80 ft. Was a packer used? SAUD  
 Diameter of well bore to bottom of seal 16 in.  
 Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
 Gravel placed from " ft. to " ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_

**(10) WATER LEVELS:**

Static level 143 ft. below land surface Date 8/25/62  
 Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

**(11) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom? R.J. STRASSER  
 Yield: 350 gal./min. with 4 ft. drawdown after 8 hrs.  
 " " " " "  
 " " " " "  
 Bailer test gal./min. with " ft. drawdown after " hrs.  
 Artesian flow g.p.m. Date \_\_\_\_\_  
 Temperature of water 53 1/2 ° Was a chemical analysis made?  Yes  No

**(12) WELL LOG:**

Diameter of well below casing \_\_\_\_\_  
 Depth drilled 248 ft. Depth of completed well 248 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
SAND SOME BINDER	0	30
SAND AND BROKEN ROCK	30	45
DRY SAND	45	74
MED TO FINE SAND	74	103
SAND, GRAVEL AND COBBLES	103	111
GRAVEL AND COBBLES	111	132
MED TO LARGE GRAVEL	132	146
FINE SAND	146	179
GRAVEL AND SAND	179	194
LARGE GRAVEL	194	198
FINE SAND	198	217
GRAVEL	217	243
SAND AND GRAVEL (CLAY BINDER)	243	248

Work started JULY 21 1962 Completed AUG 27 1962  
 Date well drilling machine moved off of well AUG 28 1962

**(13) PUMP:**

Manufacturer's Name \_\_\_\_\_  
 Type: \_\_\_\_\_ H.P. \_\_\_\_\_

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R.J. STRASSER DRILLING CO  
 (Person, firm or corporation) (Type or print)  
 Address 8110 SE SUNSET LANE PORT. 6 ORE

Drilling Machine Operator's License No. 56

[Signed] Robert J. Strasser  
 (Water Well Contractor)

Contractor's License No. 10 Date Aug 29, 1962