

ORIGINAL  
File Original and  
Duplicate with the  
STATE ENGINEER,  
SALEM, OREGON

MULTI RECEIVED  
960

WATER WELL REPORT  
STATE OF OREGON  
JUL 20 1959

State Well No. 4N/1-10A(1)  
State Permit No. G1276

(1) OWNER:

Name Portland Trailer Court  
Address 9000 N.E. Union,  
Portland, Ore.

(2) LOCATION OF WELL:

County Mult Owner's number, if any—  
1/4 Section T. R. W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED:

Threaded  Welded   
10 " Diam. from 0 ft. to 163 ft. Gage Std.  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used Star  
SIZE of perforations 3/8 in. by 1 & 1/8 in.  
1040 perforations from 145 ft. to 158 ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:

Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Was a surface seal provided?  Yes  No To what depth? 6 ft.  
Material used in seal— grout  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:

Static level 0 ft. below land surface Date \_\_\_\_\_  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Log Accepted by:

[Signed] \_\_\_\_\_ Date \_\_\_\_\_, 19\_\_\_\_  
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level R. J. Strasser Drilling Co.  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: 200 gal./min. with 12 ft. drawdown after 5 hrs.  
" 275 " " 16 " " 5 "  
" 375 " " 22 " " 5 "  
Bailer test gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well 10 inches.  
Depth drilled 163 ft. Depth of completed well 163 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Fill and surface	0	5
Sandy silt	5	23
Blue Clay	23	39
Sandy silt	39	78
Sand stone	78	81
Sandy Clay	81	89
Hard packed sand	89	123
Muddy sand	123	129
Packed sand	129	138
Water-bearing sand & Gravel	138	158
Large gravel & Boulders	158	163

Work started July 1 1959. Completed July 12 1959

(13) PUMP:

Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. J. Strasser Drilling Co.  
(Person, firm, or corporation) (Type or print)

Address 8110 S.E. Sunset Lane

Driller's well number 4008

[Signed] R. J. Strasser  
(Well Driller)

License No. 10 Date July 17, 1959