

ORIGINAL  
File Original and  
Duplicate with the  
STATE ENGINEER,  
SALEM, OREGON

RECEIVED  
MAY 15 1958

WATER WELL REPORT  
STATE OF OREGON

State Well No. 1N/1-10K(1)  
State Permit No. G 783

(1) OWNER: **STATE ENGINEER**  
Name ASSOCIATED MEAT PACKERS  
Address 8349 N. VANCOUVER AVE. PORTLAND OREGON

(2) LOCATION OF WELL:  
County Multnomah Owner's number, if any—  
1/4 Section 10 T 1 N R 1 E W.M.  
Bearing and distance from section or subdivision corner  
The well is located 2520 feet N and 795' E. from the South 1/4 corner of Section 10

(3) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):  
Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:  
Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:  
10" Diam. from 0 ft. to 97 ft. Gage Standard  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS:  
Perforated?  Yes  No  
Type of perforator used 4 way drive down  
SIZE of perforations 3/8 in. by 1 1/2 in.  
192 perforations from 57 ft. to 65 ft.  
240 perforations from 78 ft. to 88 ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:  
Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

CONSTRUCTION:  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. 20 to 24  
Was a surface seal provided?  Yes  No To what depth? \_\_\_\_\_  
Material used in seal— sand gravel & cement  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:  
Static level 24 ft. below land surface Date 4/24/58  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Log Accepted by \_\_\_\_\_  
[Signed] Frank M. Meredith Date 5-13-1958  
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Bottner Well Drilling  
Yield: 250 gal./min. with no ft. drawdown after 1 hrs.  
" 400 " " no " 1 "  
" 550 " " no " 1 1/2 "  
Pump test 900 gal./min. with 1 inch drawdown after 2 1/2 hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water 54° Was a chemical analysis made?  Yes  No

(12) WELL LOG: Diameter of well 10 inches.  
Depth drilled 97 ft. Depth of completed well 97 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Fill	0	8
Top Soil	8	16
Brown Clay	16	24
Brown Sandy Clay	24	44
Gravel	44	48
Sand & Gravel	48	50
Clean Gravel	50	71
Cemented Gravel	71	75
Yellow Sand	75	77
Clean Gravel	77	80
Cemented Gravel	80	90
Clean Gravel	90	93
Sand & Gravel	93	97

After one half hour of pumping, water turned crystal clear & sand free.

Work started April 10 1958 Completed April 25 1958

(13) PUMP:  
Manufacturer's Name WESTERN LAND ROLLER  
Type OIL LUBRICATED TURBINE H.P. 15

Well Driller's Statement:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME HAakon I. Bottner WELL DRILLING  
(Person, firm, or corporation) (Type or print)  
Address 11544 N. E. GLISAN ST. PORTLAND 16, OREGON  
Driller's well number \_\_\_\_\_  
[Signed] H. Bottner  
(Well Driller)  
License No. 109 Date MAY 1 1958