

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date of well completion.

MULT WATER WELL REPORT

STATE OF OREGON

RECEIVED

OCT 24 1974

State Well No.

IN/E-11 CC

STATE ENGINEER  
SALEM, OREGON

State Permit No.

(Do not write above this line)

(1) OWNER:

Name AMERON, N. W. Division  
Address 518 N. E. Columbia Blvd.  
Portland, Oregon

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
 Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED:

Threaded  Welded   
10-3/4" Diam. from -5 ft. to 90 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated?  Yes  No.  
Type of perforator used Mills Knife  
Size of perforations 1/4 in. by 1-1/2 in.  
96 perforations from 72 ft. to 88 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Gal./min. with ft. drawdown after hrs.  
" " " "  
" " " "  
Bailer test 75 gal./min. with 0 ft. drawdown after 2 hrs.  
Artesian flow g.p.m.  
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite  
Well sealed from land surface to 18 ft.  
Diameter of well bore to bottom of seal 14 in.  
Diameter of well bore below seal 10" in.  
Number of sacks of cement used in well seal 0 sacks  
Number of sacks of bentonite used in well seal 20 sacks  
Brand name of bentonite International Gel  
Number of pounds of bentonite per 100 gallons of water 50 lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? insufficient depth of strata 31-36'; 41-60'  
Method of sealing strata off Casing  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Multnomah Driller's well number  
SW 1/4 SW 1/4 Section 11 T.1 N R. 1 E. W.M.  
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 31 ft.  
Static level 41 ft. below land surface. Date 10/15/74  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 10"  
Depth drilled 90 ft. Depth of completed well 90 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Open sump	0	6	
Concrete, gravel, cobble	6	18	
Med. coarse brown sand	18	31	
Fine to med.coarse sand gravel	31	36	
Coarse gravel; cobble; boulders	36	41	
Med. fine to med.coarse gravel	41	49	
Coarse sand; fine gravel	49	60	
Muddy sand; gravel	60	69	
Gravel & bobble	69	80	
Fine to coarse gravel	80	82	75- gpm
Sand & gravel	82	90	

Work started 9/18/74 19 Completed 10-15-74 19  
Date well drilling machine moved off of well 10-15-74 19

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] \_\_\_\_\_ Date 10-16-74 19  
Drilling Machine Operator's License No. 751

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name A. M. JANNSEN DRILLING CO. (Type or print)  
Address 21075 S.W. Tualatin Valley Hwy. Aloha, Or. (Person, firm or corporation)  
[Signed] \_\_\_\_\_ (Water Well Contractor)  
Contractor's License No. 79 Date 10/16/74 19