

RECEIVED

MAY 29 1962

MULT

976

IN/1-12

NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

STATE ENGINEER STATE OF OREGON SALEM, OREGON (Please type or print)

State Well No. State Permit No.

(1) OWNER:

Name: RIVERSIDE GOLF AND COUNTRY CLUB
Address: 8105 N.E. 33 DRIVE PORTLAND, OREGON

(2) LOCATION OF WELL:

County: MULT, Driller's well number: 4123
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [X]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 150 ft. Gage 279

(7) PERFORATIONS:

Perforated? [X] Yes [ ] No
Type of perforator used: STAR
Size of perforations: 1 1/4 in. by 3/8 in.
450 perforations from 130 ft. to 145 ft.

(8) SCREENS:

Well screen installed [ ] Yes [X] No
Manufacturer's Name, Model No., Slot size, Diam.

(9) CONSTRUCTION:

Well seal—Material used in seal: CEMENT
Depth of seal: 20 ft. Was a packer used? No
Diameter of well bore to bottom of seal: 12 in.
Were any loose strata cemented off? [X] Yes [ ] No Depth: 16
Was a drive shoe used? [X] Yes [ ] No
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [X] Yes [ ] No
Type of water? SURFACE Depth of strata: 16
Method of sealing strata off: CEMENT

(10) WATER LEVELS:

Static level: 6 ft. below land surface Date: MAY 4, 1962
Artesian pressure: lbs. per square inch Date:

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [ ] No If yes, by whom? STRASSER
Yield: 40 gal./min. with 42 ft. drawdown after 4 hrs.

(12) WELL LOG:

Diameter of well below casing
Depth drilled: 150 ft. Depth of completed well: 150 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Entries: GREY SILT (0-40), FINE SAND (40-110), BROWN SAND (110-121), SAND AND GRAVEL (121-150)

Work started 4/17 19 62 Completed 5/7 19 62
Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name: JOHNSTON
Type: TURBINE H.P. 3

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME: RJ STRASSER DRILLING CO. (Person, firm or corporation)
Address: 8110 SE SUNSET LANE PORT ORE
Drilling Machine Operator's License No.
[Signed] Paul R. Rydman (Water Well Contractor)
Contractor's License No. 10 Date MAY 26, 19 62

