

NC

RECEIVED
OCT 12 1966

MULT
981

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE ENGINEER OF OREGON (Please type or print)

State Well No. 1N/1-13 R

State Permit No.

(1) OWNER:

Name SCHOOL DIST NO 1 MULT. COUNTY
Address 620 NE HALSEY ST.
PORTLAND, ORE.

(2) LOCATION OF WELL: JOHN ADAMS HIGH SCHOOL WELL #2
County Multnomah Driller's well number 4238
SE 1/4 SE 1/4 Section 13 T. 1N R. 1E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:

Threaded Welded
16" Diam. from 0 ft. to 190 ft. Gage 3.75
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used STAR
Size of perforations 3/8 in. by 1/4 in.
540 perforations from 157 ft. to 166 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT
Depth of seal 28 ft. Was a packer used? YES
Diameter of well bore to bottom of seal 20 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 142 ft. below land surface Date 9/28/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? STRASSER
Yield: 720 gal./min. with 16 ft. drawdown after 8 hrs.
" 600 " " 12.5 " " 2 "
" 500 " " 10 " " 2 "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 53° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing
Depth drilled 190 ft. Depth of completed well 190 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
CLAY AND BOULDERS	0	16
GRAVEL SAND, CLAY BINDER	16	39
BROWN SAND	39	44
SAND, GRAVEL AND CLAY	44	53
GRAVEL	53	71
SAND, GRAVEL AND CLAY	71	100
GRAVEL SOME CLAY	100	157
LOOSE GRAVEL, SOME SILT	157	165
SAND GRAVEL AND CLAY	165	190

Work started AUG 23 1966 Completed OCT 1 1966
Date well drilling machine moved off of well OCT 1 1966

(13) PUMP:

Manufacturer's Name
Type: H.P.
Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME R. STRASSER DRILLING CO
(Person, firm or corporation) (Type or print)
Address 8110 SE SUNSET LANE PORTLAND ORE.
Drilling Machine Operator's License No. 54 AND 57
[Signed] Robert L. Strasser
(Water Well Contractor)
Contractor's License No. 10 Date OCT 5 1966