

WELL I.D.# 16369

MULT

992

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON

AUG 26 1966

STATE OF OREGON (Please type or print)

State Well No. 1N/1-13 R

State Permit No.

(1) OWNER:

Name SCHOOL DIST. NO. 1 MULT. COUNTY
Address 620 NE HALSEY ST. PORTLAND OREGON

(2) LOCATION OF WELL: JOHN ADAMS HIGH SCHOOL

County MULT. Driller's well number 4236
SE 1/4 SE 1/4 Section 13 T. 1N R. 1E W.M.

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? STRASSER
Yield: 900 gal./min. with 14 ft. drawdown after 8 hrs.
700 " 10.5 " 2 "
500 " 6 " 2 "

(12) WELL LOG:

Diameter of well below casing RICK FILLED
Depth drilled 370 ft. Depth of completed well 350 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include: TOP SOIL, CLAY AND GRAVEL, GRAVEL, BOULDERS, CLAY, CEMENTED GRAVEL, LOOSE GRAVEL, SAND GRAVEL AND CLAY, WATER BEARING GRAVEL, BROWN SAND AND GRAVEL, CEMENTED GRAVEL, STICKY CLAY, MUDSTONE.

(3) TYPE OF WORK (check):

New Well X Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED: Threaded Welded
16" Diam. from 0 ft. to 350 ft. Gage 375

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used STAR
Size of perforations 3/8 in. by 1 1/4 in.
600 perforations from 260 ft. to 270 ft.
600 perforations from 145 ft. to 155 ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name Model No.
Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used, in seal CEMENT
Depth of seal 24 FT ft. Was a packer used? YES
Diameter of well bore to bottom of seal 20 in.
Were any loose strata cemented off? Yes No
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 138 ft. below land surface Date 8/4/66
Artesian pressure lbs. per square inch Date

Work started JUNE 20 1966 Completed AUG 20 1966
Date well drilling machine moved off of well AUG 23 1966

(13) PUMP:

Manufacturer's Name H.P.
Type:

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R J STRASSER DRILLING CO.
(Person, firm or corporation) (Type or print)

Address 8110 SE SUNSET LAVE PORTLAND ORE.

Drilling Machine Operator's License No. 54 AND 51

[Signed] Robert L. Strasser
(Water Well Contractor)

Contractor's License No. 10 Date AUG 25 1966