

WELL LABEL # L

START CARD #	1006366
--------------	---------

Form Version: 0.89

Pumped in 783 sacks of cement from the bottom up through a trimy pipe filling the well up.

04-20-2009

START CARD # 1006366

Map of well



Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301-1266
(503) 986-0900
www.wrd.state.or.us

Special Standards Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 3/10/2009 Oral approval date (if applicable): 3/10/2009

Bonded Well Constructor (name, license #, and mailing address): Robert Stadel #1523

(1) Location of Well: SW 1/4 SW 1/4 Tax lot 0400 Section 34,
Township 1 N, Range 1 E, Multnomah County
Address at well site: 400 SW 6th Ave, Portland, Oregon

(2) Start Card Number(s)(for work to be done): 1006366

(3) Name and Address of Land Owner: 400 SW 6th Ave LLC, C/O Norris, Beggs & Simpson
121 SW Morrison, Suite 200, Portland, Oregon 97204

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)
N/A

(5) The unusual site conditions which necessitate this request: Unable to bail out large basalt
chunks at 525' bgs, well is 4' from side of building, access is through a manhole into lower room so other methods
would be difficult or impossible. All water producing zones are exposed for abandonment.

(6) The proposed construction methods that the bonded well constructor believes will be
adequate for this well: (attach additional pages if needed)
Steel casing will be perforated from surface to 368' and well will be abandoned with neat cement per state standards.

04-20-2009

START CARD # 1006366

Map of well

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)

PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____